



**Power Grid Bangladesh PLC
National Load Dispatch Center (NLDC)
EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 04-12-2025

Sl.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCGP Unit-3	PDB	1*260	260	0	0	GT is under maintenance
2	Ghorasal Repowered CCGP Unit-4	PDB	1*210	240	0	0	-
3	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	-
3	Ghorasal 365 MW CCGP Unit-7	PDB	1*243+1*122	365	0	0	Gas shortage
4	Ghorasal 108 MW PP (Regent)	IPP	34*3.35	97.7	0	0	-
5	Haripur 412 MW CCGP	SBU,PDB	32*2	20	0	0	-
6	Haripur 360 MW CCGP	EGCB	1*273+1*139	412	339	8319600	-
7	Meghnaghat 450 MW CCGP (MPL)	IPP	1*236+1*125	0	0	0	Contract Expired
8	Meghnaghat CCGP(Summit)	IPP	2*150+1*150	450	0	0	-
9	Madangan-35 MW PP(Summit)	IPP	2*110+1*110	335	0	0	-
10	Siddhirgonj 210 MW TPP	PDB	3*17+1*11.3	55	0	0	-
12	Siddhirgonj 210 MW TPP	PDB	1*210	115	0	0	Under Major Overhauling
13	Siddhirgonj 2*120 MW GTPP	EGCB	2*105	208.137	0	0	-
14	Siddhirgonj 335 MW CCGP	EGCB	1*217+1*18	335	280	6509003	-
15	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0	Liquid fuel shortage
17	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	53.97	34.2	288000	-
18	Kodda 150 MW PP BRPL	PDB-RPCL	9*17.06	149.36	38	103200	-
18	Mankganj 55 MW PP (Northern)	IPP	19*3	55	50	351074	-
20	Nababganj 55 MW PP (Southern power)	IPP	19*3	55	17	53190	Liquid fuel shortage
22	Summit Power Ashulia	IPP	0	33.75	18	413400	Low gas pressure
22	Summit Power Madhabdi	IPP	3*3.67+4*8.73	23	22	514080	-
25	Gazipur 52 MW PP	RPCL	6*8.9	52.194	16	186720	Liquid fuel shortage
26	Tongi 80 MW GTPP	PDB	1*105	105	0	0	Under Maintenance of Exciter
27	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.06	300	175	893487	-
28	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	90	649440	-
29	Gazipur 100 MW PP	RPCL	6*17.5	105	50	204480	-
30	Meghnaghat 104 MW PP (OPCL)	IPP	6*18.5	104	0	0	Liquid fuel shortage
31	Mankganj 162MW PP(MPGL)	IPP	9*18	162	87	519840	FGMO
32	Spectra Solar Plant Ltd.	IPP	0	35	0	161430	-
33	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	0	0	Liquid fuel shortage
34	Unique Meghnaghat Power Limited (UMPL)	IPP	0	584	0	0	FGMO Available
35	Meghnaghat CCGP(Summit)-2	IPP	1*409+1*202	583	0	0	upstream gas valve has been kept shut by T
	JERA Meghnaghat Power Limited	IPP	250*2+268	718	401	10115350	-
	Sreepur 150 MW PP BRPL	PDB-RPCL	9*18	160	17	3600	Engine Problem
			Dhaka Area Total	6667.111	1634.2	29285894	
36	Chattogram TPP	PDB	1*210+1*210	360	0	0	1 Under Maintenance, Unit#2 Running at 15
37	Raozan 25 MW PP	IPP	3*8.9	25.5	0	0	-
38	Teknaf 20MW PP (Solartech)	IPP	0	20	0	125145	-
39	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	33	247200	-
40	Kamaphuli Hydro PP Unit-1,2,3,4, 5	PDB	2*140+3*150	230	40	964000	-
41	Sikalbaha 225MW CCGP	PDB	1*150+1*75	225	228	5332992	-
42	Sikalbaha Peaking GT	PDB	1*150	150	0	0	-
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	89	672436	Bill delay
44	Hathazari 100 MW peaking PP	PDB	11*8.9	98	31	68304	machine problem
45	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	0	0	Engine Problem
46	Juidah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	24	45120	Liquid fuel shortage
	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	42	13	492000	-
47	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	-
48	Kaptai 7 MW Solar PP	PDB	0	6	0	18285	-
49	Anwara 300 MW PP (United)	IPP	17*17+24	300	0	0	100%NEO cut for BPDB late pay PPA Sec.1
50	Jodioc Power	IPP	3*18.55+1*3.6	54.363	0	0	Liquid fuel shortage
51	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	19	64399	FGMO
52	Juidah unit-2 (Acorn)	IPP	8*13.6	100	25	288000	Liquid fuel shortage
53	Anima Energy Ltd.	IPP	6*21.2	116	0	0	FGMO
54	Mirsharar 150 MW BRPL	IPP	18.5*9	159.96	0	0	FGMO
55	SS Power	IPP	2*660	1224	560	10510908	Partial Shutdown due to maintenance
56	Cox's Bazar Wind	PDB	2*23	60	3	201600	-
57	Matarbari 2*600 MW (CPGCL)	CPGCL	2*600	1150	354	8370809.09	U1 S/D 20/NOV/25 (Maintenance Work)
			Chattogram Area Total	4895.723	1419	27401298.09	
58	Ashuganj CCGP 225 MW	APSCl	1X142+1X75	221	216	4880000	FGMO
59	Ashuganj 450 MW CCGP(North)	APSCl	1*360	353.35	0	0	Under Maintenance
60	Ashuganj 450 MW CCGP(South)	APSCl	1*360	318.81	240	5760000	able to on FGMO>machine under observat
61	Ashuganj 420 MW CCGP(East)	APSCl	284*1+116*1	393	230	6007000	-
62	Ashuganj TSK 50 MW PP	APSCl	14*3.96	46.701	0	0	-
63	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	0	0	-
64	Ashuganj 195 MW PP (APSCl-United)	IPP	20X9.73+1X16	195	0	0	-
65	Ashuganj 51 MW PP (Midland)	IPP	6X9.34	51	51	1069064	-
66	Ashuganj 150MW PP (Midland)	IPP	23X7.015	150	93	436581	-
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	machine problem
68	Chandpur 150 MW CCGP	PDB	1*106+1*57	163	108	2496457	-
69	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	99	399840	FGMO
	Import (Tipura)	IPP	0	160	96	2069780	-
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52.2	0	0	-
72	Cumilla 25 MW PP (Summit)	SIPP,REB	3*3.67+2*6.97	25	11	300740	Machine Under Maintenance
73	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	FGMO
74	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	0	Liquid fuel Shortage
75	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	0	0	FGMO
76	Sonagazi 75 MW (AC) Solar Power Plant	EGCB	0	75	0	408982	-
			Cumilla Area Total	2853.061	1144	23828424	
77	RPCL 210MW CCGP	RPCL	4*35+1*70	210	18	556800	Low gas pressure
79	Sarishabari 3 MW Solar Plant	IPP	0	2.71	0	10150	-
80	Mymensingh 200 MW PP (United)	IPP	9.78*21	200	28	336000	00%NEO cut for BPDB late pay PPA Sec.1
81	Jamalpur 115 MW PP (United)	IPP	9.78*12	115	59	1026000	00%NEO cut for BPDB late pay PPA Sec.1
82	Sultkhali 50 MW Solar PP	IPP	0	50	0	247470	-
83	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	0	0	be dispatched 12 MW, due to fuel shortage
84	Bhalrob 54.5 MW	IPP	3*18.2	54.5	0	0	Liquid fuel shortage
			Mymensingh Area Total	654.21	105	2175420	
	Moulvibazar 10 MW Solar Power Plant	IPP	1*10	0	0	49894	-
85	Fenchugonj CCGP Phase-1	PDB	2*32+1*33	90	0	0	-
86	Fenchugonj CCGP Phase-2	PDB	2*35+1*35	90	30	715920	-



**Power Grid Bangladesh PLC
National Load Dispatch Center (NLDC)
EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 04-12-2025

Sl.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
87	Kushara 163 MW CCGP (KP)	IPP	1*109+1*54	163	0	0	Major Inspection
88	Shahjibazar 330 MW CCGP	PDB	3*110	330	0	0	Under Maintenance
91	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	30	673828	Partial Shutdown due to maintenance
92	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	82	1550400	-
93	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	machine problem
94	Sylhet 225 MW CCGP	PDB	1*142+1*89	231	156	3312360	-
95	Sylhet 20 MW GTPP	PDB	1*20	20	15	380000	-
96	Shahjahanulla 25 MW PP	SIPP,REB	3*9.34	25	24	564240	-
97	Bibiyana-I 341 MW CCGP (Summit)	IPP	1*222+1*119	341	310	7347500	FGMO
98	Bibiyana-III 400 MW CCGP	PDB	285*1+134*1	420	207	5038000	due to GBC problem
99	Bibiyana South 400 MW	PDB	1*400	393	0	0	AUTHORITY INSTRUCTION
			Sylhet Area Total	2325	854	19632142	
100	Bheramara GTPP Unit-3	PDB	1*20	16	0	0	Contract Expired
**	Bheramara (HVDC)	Import	2X500	1000	844	18937454	-
101	Fardpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Engine Problem
102	Khulna 225 MW CCGP	NWPGCL	1X150+1X75	230	0	0	-
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Engine Problem
104	Bheramara 410 MW CCGP	NWPGCL	1X278+1X132	410	173	4280832	Gas shortage
105	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	0	0	Liquid fuel shortage
106	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Liquid fuel shortage
107	Mongla Onon 100 MW Solar PP	IPP	100	100	0	429840	-
108	Khulna 330 MW CCGP	PDB	1*220+1*110	336	0	0	-
109	Rampal 1320 MW (BIFPCL)	PDB	660*2	1148.28	1050	23141820	FGMO
**	HVDC(Nepal)	Import	1*40	40	0	0	-
			Khulna Area Total	3653.28	2067	46789946	
110	Patuakhali 1320 MW (RNPL)	RNPL	660*2	622	500	8027565.7	Coal shortage
110	Barisal 110 MW PP (Summit)	IPP	7X17.076	110	0	0	-
111	Bhola 33 MW PP (Venture)	NEMP	1X34.50	10	0	0	Contract Expired
112	Bhola 225 MW CCGP	PDB	2X63+1X68	194	115	2641000	Partial Shutdown of STG
113	Payra 1320 MW	BCPCL	2*622	1085.32	974	21697454.55	FGMO
114	Bhola Nutan Biddut BD LTD	IPP	2*75+1*75	220	220	5222651	MVAR Subjected to Grid Voltage
115	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	100%NEO cut for BPDB late pay,PPASec1
116	Barisal 307 MW	BCPCL	307X1	307	0	0	-
117	Barisal 1 MW Solar Plant	IPP	0	1	0	0	-
			Barishal Area Total	2699.32	1809	37588671.25	
118	Pabna 64 MW Solar Plant	PDB	11*6.6	64	0	274084	Contract Expired
118	Baghabari 71 MW GTPP	PDB	1X71	70	0	0	Gas shortage
118	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Machine Under Maintenance
119	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	-
120	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Under Maintenance
122	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	0	Two engines are under maintenance
123	Sirajgoni 225MW CCGP Unit-1	NWPGCL	1*150+1*75	214	172	4139618	FGMO
124	Sirajgoni 225MW CCGP Unit-2	NWPGCL	1*150+1*75	220	0	0	Plant is on standby as per NLDC instruction
125	Sirajgoni 225MW CCGP Unit-3	NWPGCL	1*141	220	0	0	Standby as per instruction of NLDC
126	Sirajgoni 400 MW CCGP Unit-4	NWPGCL	1*282+1*132	413.79	414	9046109	FGMO
127	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	0	Engine Problem
129	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52.2	0	0	-
130	Chapainawabganj 100 MW Peaking PP	PDB	12*8.924	104	0	0	Liquid fuel shortage
131	Bagura 113 MW PP (Confidence)-2	IPP	6*18.55+7.2	113	0	0	-
132	Bagura 113 MW PP (Confidence)-1	IPP	6*18.55	113	113	820704	-
133	Sirajgoni 6.55 MW Solar	NWPGCL	0	6.09	0	25320	-
**	Adani Power Jharkhanda Ltd	Import	2*673	1435.88	1326	25946892	-
134	Sirajgoni 68 MW Solar Park	IPP	0	68	0	290256	-
	Pabna Solar 100 MW	IPP	0	100	0	519255	-
	Sirajgoni 2 MW Wind Power Plant	PDB	0.25*8	2	0	0	Contract Expired
			Rajshahi Area Total	3518.96	2025	41062238	
135	Saidpur 150 MW Simple Cycle Power Plant	PDB	1*150	0	0	0	-
135	Barapukuria 1PP Unit-1 & 2	PDB	1*125+1*125	170	52	1264581	-
136	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	0	0	Under Maintenance
137	Rangpur 20 MW GTPP	PDB	1*20	20	0	0	-
138	Saidpur 20 MW GTPP	PDB	1*20	20	0	0	-
139	Rangpur 113 MW PP (Confidence)	IPP	9*6.984+7*7.015+3.15*2	113	43	186172	-
140	Sympa Solar Power 8 MW	IPP	0	8	0	27230.4	-
141	Energypac Power Venture Thakurgaon Ltd.	IPP	0	115	50	201896	-
142	Intraco Solar 30 MW	IPP	1*30	30	0	145469	-
143	Teesa Solar Limited	BCPCL	0	200	0	843840	-
			Rangpur Area Total	950	145	2669188.4	
			Eastern Grid Total	17395.105	5156.2	102324178.1	
			Western Grid Total	10821.56	6046	128110043.7	
			National Grid Total	28216.665	11202.2	230434221.7	

*Data collected from respective power station via Operation Information System(OIS) software.

Executive Engineer
Network Operation Division