



Power Grid Bangladesh PLC
National Load Dispatch Center (NLDC)
EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 11-12-2025

Sl.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3	PDB	1*260	260	0	0	GT is under maintenance
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	240	0	0	-
	Ghorasal TYP Unit-5	PDB	1*210	190	0	0	-
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Gas shortage
4	Ghorashal 108 MW PP (Regent)	IPP	34*3.35	97.7	0	0	-
5	Haripur GTPP	SBU,PDB	32*2	20	0	0	-
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	347	8323200	-
	Haripur 360 MW CCPP (HPL)	IPP	1*235+1*125	0	0	0	Contract Expired
7	Meghnaghat 450 MW CCPP (MPL)	IPP	2*150+1*150	450	0	0	-
8	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	-
9	Madanganj-55 MW PP(Summit)	IPP	3*17+1*11.3	55	0	0	-
12	Siddhirgonj 210 MW TYP	PDB	1*210	115	0	0	Under Major Overhauling
13	Siddhirgonj 2120 MW GTPP	EGCB	2*105	208.137	0	0	-
14	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	300	7147567	-
15	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0	Liquid fuel shortage
17	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	53.97	39.5	215640	FGMO
18	Kodda 150 MW PP BRPL	PDB-RPCL	9*17.06	149.36	45	105120	-
18	Manikganj 55 MW PP (Northern)	IPP	18.3*3	55	35	534796	Liquid fuel shortage
20	Nabatganj 55 MW PP (Southern power)	IPP	18.3*3	55	55	140247	Liquid fuel shortage
22	Summit Power Ashulia	IPP	0	33.75	22.8	443400	Low gas pressure
22	Summit Power Madhabdi	IPP	3*3.67+4*8.73	23	21	483120	-
25	Gazipur 52 MW PP	RPCL	8*8.9	52.194	17	192480	Liquid fuel shortage
26	Tongi 80 MW GTPP	PDB	1* 105	105	0	0	Under Maintenance of Exciter
27	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.06	300	137	352778	-
28	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	59	613584	-
29	Gazipur 100 MW PP	RPCL	6*17.5	105	40	165120	-
30	Meghnaghat 104 MW PP (OPCL)	IPP	6*18.5	104	0	0	Liquid fuel shortage
31	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	102	512640	FGMO
32	Spectra Solar Plant Ltd.	IPP	0	35	0	185327	-
33	Kanchan Purbachal Power Generation L	IPP	18.4*3	55	0	0	Liquid fuel shortage
34	Unique Meghnaghat Power Limited (UMI)	IPP	0	584	0	0	FGMO Available
35	Meghnaghat CCPP(Summit)-2	IPP	1*409+1*202	583	410	9239545	FGMO
	JERA Meghnaghat Power Limited	IPP	250*2+268	718	0	0	-
	Sreepur 150 MW PP BRPL	PDB-RPCL	9*18	160	0	0	Engine Problem
Dhaka Area Total				6667.111	1630.3	28654564	
36	Chattogram TYP	PDB	1*210+1*210	360	0	0	Unit #1 Under Maintenance, Unit#2 Gas Shortage
37	Raozan 25 MW PP	IPP	3*8.9	25.5	0	0	-
38	Teknaf 20MW PP (Solartech)	IPP	0	20	0	129870	-
39	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	26	108480	-
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	PDB	2*40+3*50	230	40	956000	-
41	Sikalbaha 225MW CCPP	PDB	1*150+1*75	225	223	5136263	-
42	Sikalbaha Peaking GT	PDB	1*150	150	0	0	-
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	105	453309	Bill delay
44	Hathazari 100 MW peaking PP	PDB	6*17.9	98	0	0	machine problem
45	Dohazari-Kalaish 100 MW Peaking	PDB	6*17	102	0	0	Engine Problem
46	Juldah 100 MW PP Unit-3 (Acom)	IPP	8*13.5	100	12	23040	Liquid fuel shortage
	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	42	22	477600	-
47	Chattogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	-
48	Kaptai 7 MW Solar PP	PDB	0	6	0	20641	-
49	Anwara 300 MW PP (United)	IPP	17*17+24	300	0	0	Avail.100%;NEO cut for BPDB late pay,PPASec13.2(j)
50	Jodiach Power	IPP	3*18.55+1*3.6	54.363	0	0	Liquid fuel shortage
51	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	17	51020	FGMO
52	Juldah unit-2 (Acom)	IPP	8*13.6	100	50	253440	Liquid fuel shortage
53	Anlima Energy Ltd.	IPP	6*21.2	116	0	0	FGMO
54	Mirsharai 150 MW BRPL	IPP	18.5*9	159.86	0	0	FGMO
55	SS Power	IPP	2*660	1224	612	13385453	Partial Shutdown due to maintenance
56	Cox's Bazar Wind	PDB	22*3	60	0	66240	-
57	Matarbari 2*600 MW (CPGCBL)	CPGCL	2*600	1150	354	8560000	U1 S/D 20/NOV/25 (Maintenance Work)
Chattogram Area Total				4895.723	1461	29621356	
58	Ashuganj CCPP 225 MW	APSCCL	1X142+1X75	221	202	4928000	FGMO
59	Ashuganj 450 MW CCPP(North)	APSCCL	1*360	353.35	0	0	Under Maintenance
60	Ashuganj 450 MW CCPP(South)	APSCCL	1*360	318.81	280	6730000	Unable to on FGMO>machine under observation.
61	Ashuganj 420 MW CCPP(East)	APSCCL	284*1+116*1	393	280	4183500	-
62	Ashuganj TSK 50 MW PP	APSCCL	14*3.96	46.701	0	184464	-
63	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	0	0	Gas shortage
64	Ashuganj 195 MW PP (AFSCCL-United)	IPP	20X9.73+1X16	195	0	217455	-
65	Ashuganj 51 MW PP (Midland)	IPP	6X9.34	51	51	1277360	-
66	Ashuganj 150MW PP (Midland)	IPP	23X7.015	150	100	232509	-
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	machine problem
68	Chandpur 150 MW CCPP	PDB	11*08+1*57	163	106	2352370	-
69	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	68	327840	FGMO
	Import (Tripura)	Import	0	160	120	2351040	-
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52.2	0	0	-
72	Cumilla 25 MW PP (Summit)	SIPP.REB	3*3.67+2*6.97	25	14	373040	-
73	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	FGMO
74	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	10920	Liquid fuel Shortage
75	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	0	0	FGMO
76	Sonagazi 75 MW (AC) Solar Power Plant	EGCB	0	75	0	456236	-
Cumilla Area Total				2853.061	1221	23624734	
77	RPCL 210MW CCPP	RPCL	4*35+1*70	210	11	520320	Low gas pressure
79	Sarishabari 3 MW Solar Plant	IPP	0	2.71	0	12500	-
80	Mymensingh 200 MW PP (Unite)	IPP	9.78*21	200	19	319200	-
81	Jamalpur 115 MW PP (Unite)	IPP	9.78*12	115	54	988800	-
82	Sutakhirai 50 MW Solar PP	IPP	0	50	0	283090	-
83	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	7	46560	To be dispatched 12 MW, due to fuel shortages.
84	Bhairab 54.5 MW	IPP	3*18.2	54.5	0	0	Liquid fuel shortage
Mymensingh Area Total				654.21	91	2170470	
	Moulvibazar 10 MW Solar Power Plant	IPP	1*10	0	0	69990	-
85	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	90	0	0	-
86	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	718920	-



Power Grid Bangladesh PLC
National Load Dispatch Center (NLDC)
EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 11-12-2025

Sl.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
87	Kushara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Major Inspection
88	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under Maintenance
91	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	30	687648	-
92	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	84	1756800	01 engine maintenance
93	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	machine problem
94	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	155	4309130	-
95	Sylhet 20 MW GTPP	PDB	1*20	20	15	389000	-
96	Shahjahanulla 25 MW PP	SIPP_REB	3*9.34	25	16	461280	-
97	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	315	7542500	FGMO
98	Bibiana-III 400 MW CCPP	PDB	285*1+134*1	400	200	5030000	due to GBC problem
99	Bibiana South 400 MW	PDB	1*400	383	0	0	Partial Shutdown due to maintenance
			Sylhet Area Total	2325	845	20965268	
100	Bheramara GTPP Unit-3	PDB	1X20	16	0	0	Contract Expired
**	Bheramara (HVDC)	Import	2X500	1000	890	19171818	-
101	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Engine Problem
102	Khulna 225 MW CCPP	NWPGCL	1X150+1X75	230	0	0	-
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Engine Problem
104	Bheramara 410 MW CCPP	NWPGCL	1X278+1X132	410	140	3581856	Gas shortage
105	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	17	115680	Liquid fuel shortage
106	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Liquid fuel shortage
107	Mongla Oron 100 MW Solar PP	IPP	100	100	0	443520	-
108	Khulna 330 MW CCPP	PDB	1*220+1*110	336	0	0	-
109	Rampal 1320 MW (BIFPCL)	PDB	660*2	1148.28	1061	22974550	-
**	HVDC(Nepal)	Import	1*40	40	0	0	-
			Khulna Area Total	3653.28	2108	46833424	
	Patuakhali 1320 MW (RNPL)	RNPL	660*2	622	500	7940452	Coal shortage
110	Barisal 110 MW PP (Summit)	IPP	7X17.076	110	0	0	-
111	Bhola 33 MW PP (Venture)	NENP	1X34.50	10	0	0	Contract Expired
112	Bhola 225 MW CCPP	PDB	2X63+1X98	194	100	2569000	Partial Shutdown of STG
113	Payra 1320 MW	BCPCL	2*622	1085.32	994	21521454.55	FGMO
114	Bhola Nulan Biddut BD LTD	IPP	2*75+1*75	220	220	4414281	MVAR Subjected to Grid Voltage
115	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	Avail.100%-NEO cut for BPDB late pay,PPASec13.2(i)
116	Barisal 307 MW	BCPCL	307X1	307	0	0	Under Maintenance
117	Barisal 1 MW Solar Plant	IPP	0	1	0	3235	-
			Barisal Area Total	2699.32	1814	36448422.55	
	Pabna 64 MW Solar Plant	PDB	11*6.6	64	0	301900	Contract Expired
118	Baghabari 71 MW GTPP	PDB	1X71	70	0	0	Gas shortage
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Machine Under Maintenance
119	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	-
120	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Under Maintenance
122	Katakhal 50 MW Peaking PP	PDB	6*8.7	50	0	0	Two engines are under maintenance
123	Sirajgonj 225MW CCPP Unit-1	NWPGCL	1*150+1*75	214	176	4094000	FGMO
124	Sirajgonj 225MW CCPP Unit-2	NWPGCL	1*150+1*75	220	0	0	Plant is on standby as per NLDC instruction
125	Sirajgonj 225MW CCPP Unit-3	NWPGCL	1*141	220	0	0	Standby as per instruction of NLDC
126	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1*282+1*132	413.79	414	9434181	FGMO
127	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	0	Engine Problem
129	Natore 52 MW PP (Rajanka)	IPP	6*8.92	52.2	0	0	-
130	Chapainawabganj 100 MW Peaking PP	PDB	12*8.924	104	0	0	Liquid fuel shortage
131	Bagura 113 MW PP (Confidence)-2	IPP	6*18.55+7.2	113	0	0	-
132	Bagura 113 MW PP (Confidence)-1	IPP	6*18.55	113	0	0	-
133	Sirajgonj 6.55 MW Solar	NWPGCL	0	6.09	0	31200	-
**	Adani Power Jharkhanda Ltd	Import	2*673	1435.88	1408.49	25333624	-
134	Sirajgonj 68 MW Solar Park	IPP	0	68	0	347248	-
	Pabna Solar 100 MW	IPP	0	100	0	563630	-
	Sirajgonj 2 MW Wind Power Plant	PDB	0.25*8	2	0	0	Contract Expired
			Rajshahi Area Total	3518.96	1998.49	40305783	
	Saidpur 150 MW Simple Cycle Power Plant	PDB	1*150	162.443	0	0	-
135	Barapukuria TPP Unit-1 & 2	PDB	1*125+1*125	170	0	0	Under Maintenance
136	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	0	0	Under Maintenance
137	Rangpur 20 MW GTPP	PDB	1*20	20	0	0	-
138	Saidpur 20 MW GTPP	PDB	1*20	20	0	0	-
139	Rangpur 113 MW PP (Confidence)	IPP	9*6.984+7*7.015+3.15*2	113	34	158361	-
140	Sympa Solar Power 8 MW	IPP	0	8	0	34149.72	-
141	Energypac Power Venture Thakurgaon L	IPP	0	115	35	397203	-
142	Intraco Solar 30 MW	IPP	1*30	30	0	188015	-
143	Teesta Solar Limited	BCPCL	0	200	0	1054080	-
			Rangpur Area Total	1112.443	69	1831808.72	
			Eastern Grid Total	17395.105	5248.3	105036392	
			Western Grid Total	10984.003	5989.49	125419438.3	
			National Grid Total	28379.108	11237.79	230455830.3	

*Data collected from respective power station via Operation Information System(OIS) software.

Executive Engineer
Network Operation Division