



Power Grid Bangladesh PLC
National Load Dispatch Center (NLDC)
EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS

Date : 17-12-2025

Sl.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
1	Ghorasal Repowered CCPP Unit-3	PDB	1*260	260	0	0	GT is under maintenance
2	Ghorasal Repowered CCPP Unit-4	PDB	1*210	240	0	0	Gas shortage
	Ghorasal TPP Unit-5	PDB	1*210	190	0	0	Gas shortage
3	Ghorasal 365 MW CCPP Unit-7	PDB	1*243+1*122	365	0	0	Gas shortage
4	Ghorasal 108 MW PP (Regent)	IPP	34*3.35	97.7	0	0	Gas shortage
5	Haripur GTPP	SBU,PDB	32*2	20	0	0	-
6	Haripur 412 MW CCPP	EGCB	1*273+1*139	412	329	8593200	FGMO
	Haripur 360 MW CCPP (HPL)	IPP	1*235+1*125	0	0	0	Contract Expired
7	Meghnaghat 450 MW CCPP (MPL)	IPP	2*150+1*150	450	0	0	Gas shortage
8	Meghnaghat CCPP(Summit)	IPP	2*110+1*110	335	0	0	Gas shortage
9	Madanganj-55 MW PP(Summit)	IPP	3*17+1*11.3	55	0	0	-
12	Siddhirgonj 210 MW TPP	PDB	1*210	115	0	0	Under Major Overhauling
13	Siddhirgonj 2*120 MW GTTP	EGCB	2*105	208.137	0	0	-
14	Siddhirgonj 335 MW CCPP	EGCB	1*217+118	335	335	7843003	-
15	Gagnagar 102 MW PP (Digital Power)	IPP	12*8.924	102	0	0	Liquid fuel shortage
17	Kamalaghat 54 MW PP(Banco Energy)	IPP	3*18	53.97	0	78840	FGMO
18	Kodda 150 MW PP BRPL	PDB-RPCL	9*17.06	149.36	0	0	-
18	Manikganj 55 MW PP (Northern)	IPP	19.3*3	55	35	500176	Liquid fuel shortage
20	Nababganj 55 MW PP (Southern power)	IPP	19.3*3	55	17	49962	Liquid fuel shortage
22	Summit Power Ashulia	IPP	0	33.75	20.2	419400	Low gas pressure
22	Summit Power Madhabdi	IPP	3*3.67+4*8.73	23	22	527400	-
25	Gazipur 52 MW PP	RPCL	6*8.9	52.194	16	15360	Liquid fuel shortage
26	Tongi 80 MW GTTP	PDB	1* 105	105	0	0	-
27	Kodda 300 MW PP Unit-2 (Summit)	IPP	18*17.06	300	45	357545	-
28	Kodda 149 MW PP Unit-1 (Summit)	IPP	8*18.45+8.97	149	94	390240	-
29	Gazipur 100 MW PP	RPCL	6*17.5	105	0	36480	-
30	Meghnaghat 104 MW PP (OPCL)	IPP	6*18.5	104	0	0	Liquid fuel shortage
31	Manikgonj 162MW PP(MPGL)	IPP	9*18	162	155	849600	FGMO
32	Spectra Solar Plant Ltd.	IPP	0	35	0	164099	-
33	Kanchan Purbachal Power Generation Ltd.	IPP	18.4*3	55	0	0	Liquid fuel shortage
34	Unique Meghnaghat Power Limited (UMPL)	IPP	0	584	0	0	FGMO Available
35	Meghnaghat CCPP(Summit)-2	IPP	1*409+1*202	583	550	7495642	FGMO
	JERA Meghnaghat Power Limited	IPP	250*2+268	718	0	0	Gas shortage
	Sreepur 150 MW PP BRPL	PDB-RPCL	9*18	160	0	0	Engine Problem
			Dhaka Area Total	6667.111	1618.2	27320947	
36	Chattoogram TPP	PDB	1*210+1*210	360	0	0	1 Under Maintenance, Unit#2 Gas Sho
37	Raozan 25 MW PP	IPP	3*8.9	25.5	0	0	-
38	Teknaf 20MW PP (Solartech)	IPP	0	20	0	105300	-
39	Patenga 50MW PP (Baraka)	IPP	8*6.98	50	3	95040	-
40	Karnaphuli Hydro PP Unit-1,2,3,4, 5	PDB	2*40+3*50	230	40	968000	-
41	Sikalbaha 225MW CCPP	PDB	1*150+1*75	225	226	5289600	-
42	Sikalbaha Peaking GT	PDB	1*150	150	0	0	-
43	Sikalbaha 105 MW PP (Baraka Sikalbaha)	IPP	6*17.5	105	64	316981	Bill delay
44	Hathazari 100 MW peaking PP	PDB	11*8.9	98	0	0	Engine Problem
45	Dohazari -Kalaish 100 MW Peaking	PDB	6*17	102	0	0	Engine Problem
46	Juldah 100 MW PP Unit-3 (Acorn)	IPP	8*13.5	100	0	0	Liquid fuel shortage
	Malancha, Ctg. EPZ (United)	IPP	5*8.73+3*9.34	42	17	403200	-
47	Chattoogram 108 MW PP (ECPV)	IPP	16*7	108	0	0	-
48	Kaptai 7 MW Solar PP	PDB	0	6	0	13563	-
49	Anwara 300 MW PP (United)	IPP	17*17+24	300	0	0	0%;NEO cut for BPDB late pay,PPAS
50	Jodiac Power	IPP	3*18.55+1*3.6	54.363	0	0	Liquid fuel shortage
51	Karnaphuli Power Ltd.	IPP	18.415*6+6.5	110	0	0	FGMO
52	Juldah unit-2 (Acorn)	IPP	8*13.6	100	50	253440	Liquid fuel shortage
53	Anlima Energy Ltd.	IPP	6*21.2	116	0	0	FGMO
54	Mirsharai 150 MW BRPL	IPP	18.5*9	159.86	0	0	FGMO
55	SS Power	IPP	2*660	1224	612	12267271	Partial Shutdown due to maintenance
56	Cox's Bazar Wind	PDB	22*3	60	2	46560	-
57	Matarbari 2*600 MW (CPGCL)	CPGCL	2*600	1150	355	8276363.64	1 S/D 20/NOV/25 (Maintenance Work
			Chattoogram Area Total	4895.723	1369	28035318.64	
58	Ashuganj CCPP 225 MW	APSCL	1X142+1X75	219	193	4625000	FGMO
59	Ashuganj 450 MW CCPP(North)	APSCL	1*360	353.35	0	1157500	-
60	Ashuganj 450 MW CCPP(South)	APSCL	1*360	318.81	65	1846000	re to on FGMO>machine under observ
61	Ashuganj 420 MW CCPP(East)	APSCL	284*1+116*1	393	393	7536000	-
62	Ashuganj TSK 50 MW PP	APSCL	14*3.96	46.701	0	191952	-
63	Ashuganj 55 MW PP (Precision)	QRPP	15*4	55	0	104640	-
64	Ashuganj 195 MW PP (APSCL-United)	IPP	20X9.73+1X16	195	0	451636	-
65	Ashuganj 51 MW PP (Midland)	IPP	6X9.34	51	51	1015856	-
66	Ashuganj 150MW PP (Midland)	IPP	23X7.015	150	0	160581	-
67	Titas 50 MW Peaking PP	PDB	6*8.92	52	0	0	machine problem
68	Chandpur 150 MW CCPP	PDB	1*106+1*57	163	108	2346866	-
69	Chandpur 200MW (Desh energy)	IPP	12*18.4	200	51	420000	FGMO
	Import (Tripura)	Import	0	160	122	2473920	-
71	Jangalia 52 MW PP (Lakdanavi)	IPP	6*8.92	52.2	0	0	-
72	Cumilla 25 MW PP (Summit)	SIPP,REB	3*3.67+2*6.97	25	20	401960	-
73	Feni Lanka Power	IPP	7*18.415+1*9.78	114	0	0	FGMO
74	Chowmuhani 113 MW	IPP	12*9.78+2*3.1	113	0	0	Liquid fuel Shortage
75	Chandpur 115(Doreen)	IPP	4*18.5+2*22.5	115	0	0	FGMO
76	Sonagazi 75 MW (AC) Solar Power Plant	EGCB	0	75	0	356500	-
			Cumilla Area Total	2853.061	1003	23088411	
77	RPCL 210MW CCPP	RPCL	4*35+1*70	210	163	3733440	Low gas pressure
79	Sarishabari 3 MW Solar Plant	IPP	0	2.71	0	11200	-
80	Mymensingh 200 MW PP (United)	IPP	9.78*21	200	19	187200	%,NEO cut for BPDB late pay PPA Se
81	Jamalpur 115 MW PP (United)	IPP	9.78*12	115	57	530400	-
82	Sutiakhali 50 MW Solar PP	IPP	0	50	0	267410	-
83	Tangail Palli Power Gen 22 MW	IPP	4*6.7	22	0	0	8 dispatched 12 MW, due to fuel short
84	Bhairon 54.5 MW	IPP	3*18.2	54.5	0	0	Liquid fuel shortage
			Mymensingh Area Total	654.21	239	4729650	
	Moulvibazar 10 MW Solar Power Plant	IPP	1*10	0	0	6428	-



**Power Grid Bangladesh PLC
National Load Dispatch Center (NLDC)
EVENING PEAK GENERATION AND DAY LONG ENERGY DATA OF POWER STATIONS**

Date : 17-12-2025

Sl.	Name of the Power Stations	Producer	Installed Capacity	Present Capacity	Peak Hour Generation	Energy Generated	Remarks
			Unit No. X Capacity	MW	MW	KWH	
85	Fenchugonj CCPP Phase-1	PDB	2*32+1*33	90	30	717000	-
86	Fenchugonj CCPP Phase-2	PDB	2*35+1*35	90	30	719880	-
87	Kushiara 163 MW CCPP (KP)	IPP	1*109+1*54	163	0	0	Major Inspection
88	Shahjibazar 330 MW CCPP	PDB	3*110	330	0	0	Under Maintenance
91	Shahjibazar GTPP Unit- 8 & 9	PDB	2*35	66	0	0	-
92	Shahjibazar 86MW PP (Shahjibazar)	RPP	32*2.90	86	83	1454400	01 engine maintenance
93	Shahjibazar 100 MW GTPP	PDB	1*100	100	0	0	machine problem
94	Sylhet 225 MW CCPP	PDB	1*142+1*89	231	96	2294950	-
95	Sylhet 20 MW GTPP	PDB	1*20	20	18	136000	-
96	Shahjahanulla 25 MW PP	SIPP,REB	3*9.34	25	17	350112	-
97	Bibiana-II 341 MW CCPP (Summit)	IPP	1*222+1*119	341	0	116790	FGMO
98	Bibiyana-III 400 MW CCPP	PDB	285*1+134*1	400	207	5043000	due to GBC problem
99	Bibiyana South 400 MW	PDB	1*400	383	0	0	Plant shutdown due to maintenance work
			Sylhet Area Total	2325	481	10838560	
	Rupsha 800 MW CCPP	NWPGCL	1*800	0	17	368000	-
100	Bheramara GTPP Unit-3	PDB	1X20	16	0	0	Contract Expired
**	Bheramara (HVDC)	Import	2X500	1000	902	20031272	-
101	Faridpur 50 MW Peaking PP	PDB	8*6.89	54	0	0	Engine Problem
102	Khulna 225 MW CCPP	NWPGCL	1X150+1X75	230	0	0	-
103	Gopalganj 100 MW Peaking PP	PDB	16*6.98	109	0	0	Engine Problem
104	Bheramara 410 MW CCPP	NWPGCL	1X278+1X132	410	330	6538464	Gas shortage
105	Rupsha 105 MW PP (Orion rupsha)	IPP	6*18.445	105	0	0	Liquid fuel shortage
106	Madhumati 100 MW PP	NWPGCL	6*18	105	0	0	Liquid fuel shortage
107	Mongla Orion 100 MW Solar PP	IPP	100	100	0	393120	-
108	Khulna 330 MW CCPP	PDB	1*220+1*110	336	0	0	GT Available
109	Rampal 1320 MW (BIFPCL)	PDB	660*2	1148.28	1122	22305460	-
**	HVDC(Nepal)	Import	1*40	40	0	0	-
			Khulna Area Total	3653.28	2371	49636316	
	Patuakhali 1320 MW (RNPL)	RNPL	660*2	622	502	7868319	-
110	Barisal 110 MW PP (Summit)	IPP	7X17.076	110	0	0	-
111	Bhola 33 MW PP (Venture)	NENP	1X34.50	10	0	0	Contract Expired
112	Bhola 225 MW CCPP	PDB	2X63+1X68	194	0	849000	Partial Shutdown of STG
113	Payra 1320 MW	BCPCL	2*622	1085.32	1070	20477090.91	FGMO
114	Bhola Nutan Bidut BD LTD	IPP	2*75+1*75	220	220	5325257	-
115	United Payra Power Ltd.	IPP	8*18.5+1*9.5	150	0	0	100%NEO cut for BPDB late pay,PPAS
116	Barisal 307 MW	BCPCL	307X1	307	0	0	Plant shutdown as per NLDC requirement
117	Barisal 1 MW Solar Plant	IPP	0	1	0	2647	-
			Barishal Area Total	2699.32	1792	34522313.91	
	Pabna 64 MW Solar Plant	PDB	11*6.6	64	0	281876	Contract Expired
118	Baghabari 71 MW GTPP	PDB	1X71	70	0	0	Gas shortage
	Baghabari 100 MW GTPP	PDB	1*100	100	0	0	Under Maintenance
119	Baghabari 50 MW Peaking PP	PDB	6*8.9	52	0	0	-
120	Bera 70 MW Peaking PP	PDB	9*8.29	71	0	0	Under Maintenance
122	Katakali 50 MW Peaking PP	PDB	6*8.7	50	0	0	Two engines are under maintenance
123	Sirajgonj 225MW CCPP Unit-1	NWPGCL	1*150+1*75	214	0	0	-
124	Sirajgonj 225MW CCPP Unit-2	NWPGCL	1*150+1*75	220	193	4675455	Gas shortage
125	Sirajgonj 225MW CCPP Unit-3	NWPGCL	1*141	220	0	0	Standby as per instruction of NLDC
126	Sirajgonj 400 MW CCPP Unit-4	NWPGCL	1*282+1*132	413.79	400	9261890	FGMO
127	Santahar 50 MW Peaking PP	PDB	6*8.7	50	0	0	Engine Problem
129	Natore 52 MW PP (Rajlanka)	IPP	6*8.92	52.2	0	0	-
130	Chapainawabganj 100 MW Peaking PP	PDB	12*8.924	104	0	0	Liquid fuel shortage
131	Bagura 113 MW PP (Confidence)-2	IPP	6*18.55+7.2	113	0	0	-
132	Bagura 113 MW PP (Confidence)-1	IPP	6*18.55	113	0	0	-
133	Sirajgonj 6.55 MW Solar	NWPGCL	0	6.09	0	27000	-
**	Adani Power Jharkhanda Ltd	Import	2*673	1435.88	1421.81	23989091	-
134	Sirajgonj 68 MW Solar Park	IPP	0	68	0	302256	-
	Pabna Solar 100 MW	IPP	0	100	0	577340	-
	Sirajgonj 2 MW Wind Power Plant	PDB	0.25*8	2	0	0	Contract Expired
			Rajshahi Area Total	3518.96	2014.81	39114908	
	Saidpur 150 MW Simple Cycle Power Plant	PDB	1*150	162.443	0	0	-
135	Barapukuria TPP Unit-1 & 2	PDB	1*125+1*125	170	57	1344872	Machine Problem
136	Barapukuria 275 MW TPP Unit-3	PDB	1*275	274	0	0	Under Maintenance
137	Rangpur 20 MW GTPP	PDB	1*20	20	0	0	-
138	Saidpur 20 MW GTPP	PDB	1*20	20	0	0	-
139	Rangpur 113 MW PP (Confidence)	IPP	9*6.984+7*7.015+3.15*2	113	60	147801	-
140	Sympa Solar Power 8 MW	IPP	0	8	0	33491.88	-
141	Energypac Power Venture Thakurgaon Ltd.	IPP	0	115	50	193668	-
142	Intraco Solar 30 MW	IPP	1*30	30	0	180989	-
143	Teesta Solar Limited	BCPCL	0	200	0	977760	-
			Rangpur Area Total	1112.443	167	2878581.88	
			Eastern Grid Total	17395.105	4710.2	94012886.64	
			Western Grid Total	10984.003	6344.81	126152119.8	
			National Grid Total	28379.108	11055.01	220165006.4	

*Data collected from respective power station via Operation Information System(OIS) software.

Executive Engineer
Network Operation Division