

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month December, 2025

Day: Monday

Date : 29-12-2025

Probable Maximum Demand : 11300.00 MW Probable Maximum Generation : 11300.00 MW

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28-Dec-25 (Yesterday)		29-12-2025 (Today)		28.12.25 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/Oil/ Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
<b>(A) Plants in operation:</b>												
1	Ghorasal Repowered CAPP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work
2	a) Ghorasal Repowered CAPP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	0	180			Gas Shortage
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	175	175	190		Gas Shortage
3	Ghorasal 365 MW CAPP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	260	260	365		Gas Shortage
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	98	98	108		Gas Shortage
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage
	Haripur GTPP	Gas (PDB)	1 x 32			0	0	0	0			
6	Meghnaghat 450 MW CAPP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	450	450	450		Gas Shortage
7	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling
8	Haripur 412 MW CAPP	Gas (EGCB)	1x273+1x139	412	400	356	341	412	412			
9	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	208	0	0	208	208	208		Gas Shortage
10	Siddhirganj 335 MW CAPP	Gas (EGCB)	1 x 217+1x118	335	335	240	270	335	335			
11	Meghnaghat 335MW CAPP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	335	335	335		Gas Shortage
12	Madanganj-55 MW PP (Summit)	HFO (IPP)	x17.08+1x11.	55	55	0	0	55	55			
13	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	7	7			
	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90			0	0	0	0			
14	Summit Power Ashula	Gas (SIPP, REB)	6x3.67+7x8.72	45	45	24	23.5	3.3	3.3	33		
	Summit Power Madhabdi	Gas (SIPP, REB)	6x3.67+7x8.73	35	35	22	22	22	22			
	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73									
	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73									
15	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	8	52	52			
16	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	17	34	105	105			
17	Kodda 150MW PP	HFO BR-Power gen	9x17.06	149	149	32	0	149	149			
18	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	25	21.5	54	54			
19	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	45	0	300	300			
20	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	x18.415+1x8.9	149	149	98	130	149	149			
21	Nabaganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	0	35	55	55			
22	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	22	55	55			
23	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	104	104			
24	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	60	31	162	162			
25	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	6	0	12	0			
26	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	0	55	55			
	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45									
27	Unique Meghnaghat 584MW CAPP	Gas (IPP)	1x400+1x184	584	584	0	0	420	420	584		Under maint.
28	Meghnaghat 583 MW CAPP(Summit)	Gas (IPP)	1x390+1x193	583	583	350	400	583	583			
29	Meghnaghat (Jera) 718MW CAPP	Gas (IPP)	240*2+238	718	718	0	0	718	718	718		Gas Shortage
30	Sripur 150 MW	HFO BR-Power gen	150	160	160	0	60	160	160			
<b>Dhaka Zone Total</b>				<b>6767</b>	<b>6608</b>	<b>1292</b>	<b>1398</b>	<b>5523</b>	<b>5511</b>	<b>2659</b>	<b>959</b>	
31	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	86	86	0	0			
32	Chattogram TPP	Gas (PDB)	2 x 210	420	360	0	0	0	360			Gas Shortage
33	Kaptai 7 MW Solar PP	Solar (PDB)	6	6	6	2.85	0	3	0			
34	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	26	26			
35	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	15	0	19	0			
36	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50			
37	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	14	21	105	105			
38	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	0	0	0	0	0	150		Under maint.
39	Sikalbaha 225 MW CAPP	Gas (PDB)	1 x 150+1 x 75	225	225	70	220	220	220			
40	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.9	300	300	0	0	300	300			
41	Jaldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	100	100			
42	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	98	0	0	50	50			
43	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	40	56			
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			14	18	5	9			
44	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	108	108			
45	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54			
46	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.8	110	110	0	0	110	110			
47	Jaldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	25	100	100			
48	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	116	116			
49	Mirsharai 150 MW	HFO BR-Power gen	9x18.5	163	160	0	0	160	160			
50	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	1152	1165	1224	1224			
51	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	2x575	1150	1150	770	740	745	745	410		Machine Problem
52	Cox's Bazar Wind PP	(Wind) (IPP)	1x60	60	60	0	0	0	6			
<b>Chattogram Zone Total</b>				<b>4916</b>	<b>4849</b>	<b>2124</b>	<b>2275</b>	<b>3535</b>	<b>3539</b>	<b>360</b>	<b>560</b>	
53	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	47	35	20	47	47			
54	Ashuganj 225 MW CAPP	Gas (APSCL)	1x142+1*75	221	221	34	86	221	221			
55	Ashuganj 450 MW CAPP(South)	Gas (APSCL)	1x360	360	360	0	0	318.81	318.81	360		Under Maintenance
56	Ashuganj 450 MW CAPP(North)	Gas (APSCL)	1x361	360	360	300	270	353	353			
57	Ashuganj 420 MW CAPP(East)	Gas (APSCL)	1x284+1x116	400	400	225	215	393	393			
58	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*16	195	195	0	0	195	195			
59	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x3.34	51	51	31	51	51	51			
60	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	20	150	150			
61	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	0	0			
62	Chandpur 150 MW CAPP	Gas (PDB)	1X106+1x57	163	163	112	111	163	163			
63	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	29	21	200	200			
	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90			0	0	0	0			
64	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52.2	52.2			
65	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	11	11	20.84	20.84			
66	Feni 114 MW (Lakdanavi)	HFO (IPP)	*118.415+1*9.7	114	114	0	0	114	114			
67	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	113	113			
68	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.4	115	115	0	0	115	115			
69	Ashuani 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	5	0	55	55			
70	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)	1x75	75	75	32	0	55	0			Test run
**	Impoport (Tripura)	India		160	160	102	98	0	0			
<b>Cumilla Zone Total</b>				<b>2914</b>	<b>2908</b>	<b>916</b>	<b>903</b>	<b>2617</b>	<b>2562</b>	<b>0</b>	<b>360</b>	
71	RPCL 210MW CAPP	Gas (IPP)	4x35+1x70	210	202	35	32	157.5	157.5	170		Gas Shortage
72	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	59	59	60	60			
73	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	19	20	20			
74	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	0	0			
75	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	25.05	0	9.01	0			
76	Bhairab 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0.36	54.5	54.5			
77	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	0	22	22			
<b>Mymensingh Zone Total</b>				<b>654</b>	<b>646</b>	<b>139</b>	<b>110</b>	<b>314</b>	<b>314</b>	<b>170</b>	<b>0</b>	

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	28-Dec-25 (Yesterday)		29-12-2025 (Today)		28.12.25 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)			
78	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32-1x33	97	70	40	40	38	38			Under maint.	
79	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	0	0				
80	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	0	0	0	0				
	Hobgiganj 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90										
81	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	30	30	30	30			Unit-9 Under maint.	
82	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330 Under maint.	
83	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	159	159	0	0				
84	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	0	0				
85	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	25	25				
86	Bibiana-III 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	160	305	341	341				
87	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	212	212	210	210				
88	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0			383 HGPI Due	
89	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run	
90	Shahjibazar 86MW PP (Shahjibazar)	Gas (NENP)	3x2.90	86	86	83	83	83	83				
	Moulvibazar 10 MW Solar Power Plant	Solar IPP	1*10			9	0	0	0				
<b>Khulna Zone Total</b>					<b>2350</b>	<b>2305</b>	<b>740</b>	<b>876</b>	<b>727</b>	<b>727</b>	<b>0</b>	<b>778</b>	
	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20			0	0	0	0				
91	Bheramara 410 MW CAPP	Gas (NWP/IGCL)	x 278+1 x 13	410	410	0	0	410	410			410 Gas Shortage	
92	Fairpur 50 MW Peaking PP	HFO (PDB)	6x6.98	54	54	0	0	42	42				
93	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	50				
94	Khulna 225 MW CAPP	HSD/ Gas (NWP/IGCL)	1 x 150+1x75	230	230	0	0	230	230				
95	Rupsha 102 MW PP (Orion rupsha)	HFO (IPP)	6x18.415	105	105	0	0	105	105				
96	Madhumati 100 MW PP	HFO (NWP/IGCL)	6x18.415	105	105	0	0	105	105				
97	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	35	0	35	0	0				
98	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	2x617	1234	1234	996	863	0	0				
98	Khulna 330 MW CAPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	330	330				
**	Rupsha 800 MW CAPP	Gas/HSD (NWP/IGCL)											
**	Bheramara (HVDC)	India		1000	1000	433	444	0	0				
**	Nepal	Nepal		40	40	0	0	0	0				
<b>Khulna Zone Total</b>					<b>3723</b>	<b>3723</b>	<b>1464</b>	<b>1307</b>	<b>1307</b>	<b>1272</b>	<b>410</b>	<b>0</b>	
99	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110				
100	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	40	0	0	0	0				
101	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	100	140	136	136				
102	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	965	990	1085.32	1085.32				
103	Potukhali 150MW PP (UPPL)	HFO (IPP)	x18.415+1x9.207	150	150	0	0	150	150				
104	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	0	0	307	307			307 Unit-2 Under maint	
105	Barisal 1 MW Solar PP	Solar (BPDB)	1x1	1	1	0.09	0	1	1				
106	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
	Patukhali 1320 MW (RNPL)	Coal RPCL	660*2			350	350	0	0			Test run	
<b>Barishal Zone Total</b>					<b>2266</b>	<b>2236</b>	<b>1635</b>	<b>1700</b>	<b>2009</b>	<b>2009</b>	<b>0</b>	<b>307</b>	
107	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0			71 Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0			100 Under maint.	
108	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	40	40				
109	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	32	32				
110	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	0	0				
111	Katakali 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	32				
112	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	28	28				
113	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/IGCL)	1x150+1x75	210	210	30	174	214	214			36 Gas Shortage	
114	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/IGCL)	1x150+1x75	220	220	189	180	220	220				
115	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/IGCL)	1x141+1x79	220	220	0	0	220	220			220 Gas Shortage	
116	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	382	414	413.79	413.79				
	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90										
117	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52.2	52.2				
118	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	113	113				
119	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	113	113				
	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79										
120	Sirajgonj 6.55 MW Solar	Solar (NWP/IGCL)	1x6	6	6	1.01	0	2	0				
121	Sirajgonj 68 MW Solar Park	Solar (IPP)	68	68	68	12	0	55	0				
122	Pabna Solar 100 MW	Solar (IPP)	100	100	100	16	0	90	0				
123	Sirajgonj 2 MW Wind Power Plant	Wind (BPDB)	2	2	2	0	0	0	0				
124	Pabna 64 MW Solar Plant		65	65	65	9.01	0	0	0				
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1436	1262	1385	1436	1436				
<b>Rajshahi Zone Total</b>					<b>3577</b>	<b>3517</b>	<b>1901</b>	<b>2153</b>	<b>3061</b>	<b>2914</b>	<b>327</b>	<b>100</b>	
125	Barapukuria TPP Unit-1 & 2	Coal (PDB)	2x 125	250	170	53	54	55	55			116 Under maint U-2	
126	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0			274 Under maint	
127	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
128	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18x 2*3	113	113	0	34	113	113				
129	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	14	14				
130	Majpara, Tutulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	1.4	0	3.2	0				
131	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	35	115	115				
132	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	4	0	17	0				
133	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	30	0	74.33	0				
134	Saidpur 150 MW Simple Cycle Power Plant	HSD PDB	1*150	162	162	0	0	0	0				
<b>Rangpur Zone Total</b>					<b>1192</b>	<b>1112</b>	<b>88</b>	<b>123</b>	<b>392</b>	<b>297</b>	<b>0</b>	<b>390</b>	
<b>Sub-total: Plants in operation</b>					<b>28359</b>	<b>27904</b>	<b>10299.7</b>	<b>10845</b>	<b>19493</b>	<b>19145</b>	<b>3926</b>	<b>3454</b>	
<b>(b) Plants under long term maintenance/ contract expired</b>													
	Katpali 52 MW PP (Sinha)	HFO (IPP)	7x7.90			0	0	0	0				
	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924			0	0	0	0				
	Bosila 108MW PP(ICI)	HFO (IPP)	2x8.775+1x3.5			0	0	0	0				
<b>Sub-Total: Plants under long term maintenance/ contract expired</b>					<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	
<b>134 Gross Total</b>					<b>28359</b>	<b>27904</b>	<b>10300</b>	<b>10845</b>	<b>19493</b>	<b>19145</b>	<b>3926</b>	<b>3454</b>	
<b>(C) Actual data of 28.12.25 Yesterday Sunday :</b>													
01.	Max. Demand at eve. peak (Generation end)	:	10845	MW, at = 18:00 Hr.									
02.	Evening-peak Generation (Generation end)	:	10845	MW, at = 18:00 Hr.									
03.	Highest Generation (Generation end)	:	10845	MW, at = 18:00 Hr.									
04.	Day Peak Demand	:	10300	MW, at = 12:00 Hr.									
05.	Day-peak Generation (Generation end)	:	10300	MW, at = 12:00 Hr.									
06.	Minimum Generation (Generation end)	:	7153	MW, at = 05:00 Hr.									
	Evening Peak Load-shed (Sub-station end)	:	0	MW, at = 05:00 Hr.									
07.	Generation shortfall at evening peak due to :	:											
	a) Gas/LF limitation	:	3926	MW									
	d) Coal supply Limitation	:	0	MW									
	b) Low water level in Kaptai lake	:	0	MW									
	c) Plants under shut down/ maintenance	:	3454	MW									
08.	Total Energy (Generation + Import)	:	225.47	MW									
	By Gas =	88.364	MW	By Oil =	4.781	MW							
	By Coal =	90.376	MW	Hydro&Wind=	2.077	MW							
	By Solar=	1.136	MW	Imported=	38.739	MW							
09.	Total Gas Supplied	:	694	MMCFD									
<b>(D) Forecast of 29-12-2025 (Today) :</b>													
01.	Probable Maximum Demand at Day Peak:		10200.00	MW									
02.	Probable Maximum Demand at Evening Peak:		11300.00	MW									
03.	Probable Maximum Generation at Evening Peak:		11300.00	MW									
04.	Probable Load Shed:		0									At evening peak (Sub-station end)	
05.	Probable Total Energy Generation:		225.44	MW									
06.	Probable Maximum Temperature:		25.00	°C									
* Active Power ** Imported Power													
#Remarks: Highest Generation 16794 MW on 23-07-2025 at 21:00													
										(Md. Helalur Rahman) Deputy Secretary, Generation			