

Bangladesh Power Development Board											Office of the Member, Generation Tel : 9564667, 9551095										
DAILY ELECTRICITY GENERATION REPORT																					
Month February, 2026											Day: Thursday			Date: 13-02-2026							
Probable Maximum Demand : 8780.00 MW											Probable Maximum Generation : 8780.00 MW										
Sl. No.	Name of Power Station	Nos. of Unit x Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12-Feb-25 (Yesterday)		13-02-2026 (Today)		12.02.25 (Yesterday)		Status of Machines under shut-down/ Maintenance										
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date								
					Day	Evening	Day	Evening	Day	Evening											
(A) Plants in operation:																					
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work									
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	230	230	180		Gas Shortage									
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	190	190	190		Gas Shortage									
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	0	0	365		Gas Shortage									
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	98	98	108		Gas Shortage									
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage									
	Haripur GTPP	Gas (PDB)	1 x 32			0	0	0	0												
6	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	450	450	450		Gas Shortage									
7	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0	115		Under Overhauling									
8	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	322	381	412	412												
9	Siddhirganj 2*120 MW GTPP	Gas (EGCB)	2 x 105	210	208	0	0	208	208	208		Gas Shortage									
10	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x118	335	335	240	335	335	335												
11	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	335	335	335		Gas Shortage									
12	Madanganj-55 MW PP(Summit)	HFO (IPP)	x17.08+1x11.1	55	55	0	0	55	55												
13	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	0	0	0	0											
	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90			0	0	0	0												
	Summit Power Ashulia	Gas (SIPP, REB)	6x3.67+7x8.73	45	45	0	0	33	33												
	Summit Power Madhabdi	Gas (SIPP, REB)	6x3.67+7x8.73	35	35	10	4	22	22												
	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73																		
	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73																		
15	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	0	0	52	52												
16	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	0	0	105	105												
17	Kodda 150MW PP	HFO BR-Power gen	9x17.06	149	149	0	0	149	149												
18	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	0	54	54												
19	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	0	0	300	300												
20	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	x18.415+1x8.9	149	149	0	0	149	149												
21	Nababganj 55 MW PP (Southern power)	HFO (IPP)	3x19.3	55	55	0	0	55	55												
22	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	0	0	55	55												
23	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	104	104												
24	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	0	0	162	162												
25	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	0	0	31	0												
26	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	0	0	55	55												
	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45																		
27	Unique Meghnaghat 584MW CCGP	Gas (IPP)	1x400+1x184	584	584	0	0	0	0	184		ST Under maint.									
28	Meghnaghat 583 MW CCGP(Summit)	Gas (IPP)	1x390+1x193	583	583	390	495	583	583	88		Gas Shortage									
29	Meghnaghat (Jera) 718MW CCGP	Gas (IPP)	240*2+238	718	718	0	0	718	718	718		Gas Shortage									
30	Sripur 150 MW	HFO BR-Power gen	150	160	160	17	0	160	160												
Dhaka Zone Total				6767	6608	979	1215	5100	5069	2747	559										
31	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	40	40	0	0												
32	Chattogram TPP	Gas (PDB)	2 x 210	420	360	0	0	0	0	360		Gas Shortage									
33	Kaptai 7 MW Solar PP	Solar (PDB)	6	6	6	1.92	0	4	0												
34	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	0	26	26												
35	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	20	0												
36	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	0	0	50	50												
37	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	0	0	105	105												
38	Sikalbaha Peaking GT	Gas (PDB)	1 x 150	150	0	0	0	0	0	150		Under maint.									
39	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	186	224	225	225												
40	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.9	300	300	0	0	300	300												
41	Jaldah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	100	100												
42	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	98	0	0	51	51												
43	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	24	24												
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			5	2	35	35												
44	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	0	108	108												
45	Sikalbaha 54 MW PP (Jodiac Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54												
46	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.8	110	110	0	0	110	110												
47	Jaldah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	100	100												
48	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	0	0	116	116												
49	Mirsharai 150 MW	HFO BR-Power gen	9x18.5	163	160	0	0	163	163												
50	Chattogram 2*612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	306	370	1224	1224												
51	Matarbari 2*600 MW (CPGCL)	Coal (CPGCL)	2x575	1150	1150	420	320	675	675	830		Machine Problem									
52	Cox's Bazar Wind PP	(Wind) (IPP)	1x60	60	60	15	12	24	30												
Chattogram Zone Total				4916	4849	986	968	3514	3496	360	980										
53	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	47	34	20	47	47												
54	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1*75	221	221	190	196	221	221												
55	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	280	320	318.81	318.81												
56	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	295	305	353	353												
57	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	0	0	393	393	400		Gas Shortage									
58	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20*9.73+1*116	195	195	26	26	195	195												
59	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x3.34	51	51	51	26	51	51												
60	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	0	0	150	150												
61	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	0	47	47												
62	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	50	102	163	163												
63	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	0	0	200	200												
	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90			0	0	0	0												
64	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52.2	52.2												
65	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	8	8	24.5	24.5												
66	Feni 114 MW (Lakdanavi)	HFO (IPP)	11x18.415+1*9.7	114	114	0	0	114	114												
67	Chowmuhani 113 MW	HFO (IPP)	12*9.78+2*3.1	113	113	0	0	113	113												
68	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.4	115	115	0	0	115	115												
69	Ashuaganj 55 MW PP (Precision)	Gas (NENP)	15*4	55	55	0	0	55	55												
70	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)	1x75	75	75	36	0	65	0			Test run									
**	Impoport (Tripura)	India		160	160	14	16	0	0												
Cumilla Zone Total				2914	2908	984	1019	2678	2613	400	0										
71	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	165	158	157.5	157.5	44		Gas Shortage									
72	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	66	45	60	60												
73	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	19	19	20	20												
74	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	1	0	2.1	0												
75	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	22.38	0	41	0												
76	Bheirob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	54.5	54.5												
77	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	4	0	22	22												
Mymensingh Zone Total				654	646	277	222	357	314	44	0										

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	12-Feb-25 (Yesterday)		13-02-2026 (Today)		12.02.25 (Yesterday)		Status of Machines under shut-down/ Maintenance	
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening				
78	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	30	30	30			
79	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	23	23	0	0			
80	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	138	150	163	163			
	Hobganga 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90									
81	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	20	30	30	30			Unit-9 Under maint.
82	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	0	0			330 Under maint.
83	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	100	98	100	100			
84	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	20	20			
85	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	0	0	0			
86	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	305	315	341	341			
87	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	75	357	385	385			
88	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0			383 HGPI Due
89	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0			Test run
90	Shahjibazar 86MW PP (Shahjibazar)	Gas (NENP)	3x2.90	86	86	5	86	86	86			
	Moulvibazar 10 MW Solar Power Plant	Solar IPP	1*10			4	0	0	0			
	Khulna Zone Total			2350	2305	717	1089	1155	1155	0	748	
	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20			0	0	0	0			
91	Bheramara 410 MW CAPP	Gas (NWP/CL)	x 278+1 x 13	410	410	369	374	410	410			
92	Fariapur 50 MW Peaking PP	HFO (PDB)	6x6.98	54	54	0	0	44	44			
93	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	50			
94	Khulna 225 MW CAPP	HSD/ Gas (NWP/CL)	1 x 150+1x75	230	230	0	0	230	230			
95	Rupsha 102 MW PP (Orion rupsha)	HFO (IPP)	6x18.415	105	105	0	0	105	105			
96	Madhumati 100 MW PP	HFO (NWP/CL)	6x18.415	105	105	0	0	105	105			
97	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	47	0	85	0	0			
98	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	2x617	1234	1234	391	407	617.1	617.1			Under maint.
98	Khulna 330 MW CAPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	330	330			
**	Rupsha 800 MW CAPP	Gas/HSD (NWP/CL)										Test Run
**	Bheramara (HVDC)	India		1000	1000	239	711	0	0			
**	Nepal	Nepal		40	40	0	0	0	0			
	Khulna Zone Total			3723	3723	1046	1492	1976	1891	0	827	
99	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	0	110	110			
100	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50	40	10	0	0	0	0			
101	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	100	130	130	130			
102	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	250	290	1085.32	1085.32			
103	Potukhali 150MW PP (UPPL)	HFO (IPP)	x18.415+1x9.34	150	150	0	0	150	150			
104	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	167	180	307	307			
105	Barisal 1 MW Solar PP	Solar (BPDB)	1x1	1	1	0.07	0	1	0			
106	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	180	220	220	220			
	Potukhali 1320 MW (RNPL)	Coal RPCL	660*2			0	0	0	0			Test run
	Barishal Zone Total			2266	2236	697	820	2003	2002	0	0	
107	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100		Under maint.
108	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	0	0			
109	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	0	0			
110	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	50	50			
111	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	32			
112	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	28	28			
113	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/CL)	1x150+1x75	210	210	153	169	214	214			
114	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/CL)	1x150+1x75	220	220	0	0	220	220	220		Gas Shortage
115	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/CL)	1x141+1x79	220	220	0	0	220	220	220		Gas Shortage
116	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	338	340	413.79	413.79			
	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90									
117	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52.2	52.2			
118	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	0	113	113			
119	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	0	113	113			
	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79									
120	Sirajgonj 6.55 MW Solar	Solar (NWP/CL)	1x6	6	6	2.67	0	5	0			
121	Sirajgonj 68 MW Solar Park	Solar (IPP)	68	68	68	30	0	61	0			
122	Pabna Solar 100 MW	Solar (IPP)	100	100	100	58	0	100	0			
123	Sirajgonj 2 MW Wind Power Plant	Wind (BPDB)	2	2	2	0	0	0	0			
124	Pabna 64 MW Solar Plant			65	65	26.79	0	50	0			
**	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1436	823	872	1436	1436			748 Under maint.
	Rajshahi Zone Total			3577	3517	1431	1381	3108	2892	511	848	
125	Barapukuria TPP Unit-1 & 2	Coal (PDB)	2x 125	250	170	55	55	55	55			115 Under maint U-2
126	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0			274 Under maint.
127	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	20	20			
128	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18x 2*3	113	113	0	0	113	113			
129	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	14	14			
130	Majpara, Tutulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	2.8	0	5.2	0			
131	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	0	115	115			
132	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	14	0	30	0			
133	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	76	0	158	0			
134	Saidpur 150 MW Simple Cycle Power Plant	HSD PDB	1*150	162	162	0	0	0	0			
	Rangpur Zone Total			1192	1112	148	55	510	317	0	389	
	Sub-total: Plants in operation			28359	27904	7265.6	8261	20401	19749	4062	4351	
(b) Plants under long term maintenance/ contract expired												
	Katpali 52 MW PP (Sinha)	HFO (IPP)	7x7.90			0	0	0	0			
	Jamulpur 95 MW PP(Powerpac)	HFO (IPP)	12x8.924			0	0	0	8			
	Bosila 108MW PP(ICI)	HFO (IPP)	2x8.775+1x3.5			0	0	0	0			
	Sub-Total: Plants under long term maintenance/ contract expired			0	0	0	0	8	0	0	0	
134	Gross Total			28359	27904	7266	8261	20409	19749	4062	4351	
(C) Actual data of 12.02.25 Yesterday/Wednesday :												
01.	Max. Demand at eve. peak (Generation end)					8261 MW, at = 19:00 Hr.						
02.	Evening-peak Generation (Generation end)					8261 MW, at = 19:00 Hr.						
03.	Highest Generation (Generation end)					8261 MW, at = 19:00 Hr.						
04.	Day Peak Demand					7266 MW, at = 09:00 Hr.						
05.	Day-peak Generation (Generation end)					7266 MW, at = 09:00 Hr.						
06.	Minimum Generation (Generation end)					5872 MW, at = 16:00 Hr.						
	Evening Peak Load-shed (Sub-station end)					0 MW, at = 16:00 Hr.						
07.	Generation shortfall at evening peak due to :											
	a) Gas/LF limitation					4062 MW						
	d) Coal supply Limitation					0 MW						
	b) Low water level in Kaptai lake					0 MW						
	c) Plants under shut down/ maintenance					4351 MW						
08.	Total Energy (Generation + Import)					171.71 MKWh						
	By Gas = 98.841 MKWh					By Oil = 0.888 MKWh						
	By Coal = 37.068 MKWh					Hydro&Wind= 0.610 MKWh						
	By Solar= 3.973 MKWh					Imported= 30.326 MKWh						
09.	Total Gas Supplied					742 MCFD						
(D) Forecast of 13-02-2026 (Today) :												
01.	Probable Maximum Demand at Day Peak:					8960 MW						
02.	Probable Maximum Demand at Evening Peak:					8780 MW						
03.	Probable Maximum Generation at Evening Peak:					8780 MW						
04.	Probable Load Shed:					0						At evening peak (Sub-station end)
05.	Probable Total Energy Generation:					184.45 MKWhr.						
06.	Probable Maximum Temperature:					28.00°C						
* Active Power ** Imported Power												
#Remarks: Highest Generation 16794 MW on 23-07-2025 at 21:00												
(Md. Helalur Rahman) Deputy Secretary, Generation												