

**Bangladesh Power Development Board**  
**DAILY ELECTRICITY GENERATION REPORT**

Office of the Member, Generation  
Tel : 9564667, 9551095

Month April, 2026

Day: Monday

Date: 12-05-2026

Probable Maximum Demand : 15100.00 MW Probable Maximum Generation : 15100.00 MW

Sl. No.	Name of Power Station	Nos. of Unit x Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11-May-25 (Yesterday)		12-05-2026 (Today)		11.05.25 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for : Gas/Coal/oil/Water Limitation MW		Machines shut down (MW)	Description/ Remarks	Probable start-up date
					Day	Evening	Day	Evening	Day	Evening			
<b>(A) Plants in operation:</b>													
1	Ghorasal Repowered CCGP Unit-3 (GT)	Gas (PDB)	1 x 260	260	260	0	0	0	0	260		Under project work	
2	a) Ghorasal Repowered CCGP Unit-4	Gas (PDB)	1 x 210	210	180	0	0	230	230	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas (PDB)	1 x 210	210	190	0	0	190	190	190		Gas Shortage	
3	Ghorasal 365 MW CCGP Unit-7	Gas (PDB)	1x 254+1x 126	365	365	0	0	260	260	365		Gas Shortage	
4	Ghorasal 108MW PP (Regent)	Gas (IPP)	34x3.35	108	108	0	0	98	98	108		Gas Shortage	
5	Tongi 80 MW GTPP	Gas (PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
	Haripur GTPP	Gas (PDB)	1 x 32			0	0	0	0				
6	Meghnaghat 450 MW CCGP(MPL)	Gas (IPP)	2x140+1x170	450	450	0	0	450	450	450		Gas Shortage	
7	210 MW Siddhirganj TPP	Gas (PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
8	Haripur 412 MW CCGP	Gas (EGCB)	1x273+1x139	412	400	352	332	412	412				
9	Siddhirganj 2120 MW GTPP	Gas (EGCB)	2 x 105	210	208	0	0	210	210	208		Gas Shortage	
10	Siddhirganj 335 MW CCGP	Gas (EGCB)	1 x 217+1x116	335	335	306	300	335	335				
11	Meghnaghat 335MW CCGP(Summit)	Gas (IPP)	2x110+1x110	335	335	0	0	335	335	335		Gas Shortage	
12	Madanganj-55 MW PP (Summit)	HFO (IPP)	x17.08+1x11.	55	55	30	55	55	55				
13	Gagnagar 102 MW PP (Digital Power)	HFO (IPP)	12x8.924	102	102	0	10	7	7				
	Narsingdi 22 MW PP (Doreen)	Gas (SIPP, REB)	8x2.90			0	0	0	0				
14	Summit Power Ashula	Gas (SIPP, REB)	6x3.67+7x8.73	45	45	19	18	33	33				
	Summit Power Madhabdi	Gas (SIPP, REB)	6x3.67+7x8.73	35	35	14	14	14	14				
	Maona 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73										
	Rupganj 33 MW PP(Summit)	Gas (SIPP, REB)	4x8.73										
15	Gazipur 52 MW PP	HFO (RPCL)	6x8.90	52	52	40	51	52	52				
16	Gazipur 100 MW PP	HFO (RPCL)	6x18.415	105	105	34	70	105	105				
17	Kodda 150MW PP	HFO BR-Power gen	9x17.06	149	149	0	30	149	149				
18	Kamalaghat 54 MW PP (Banco Energy)	HFO (IPP)	3x18.69	54	54	0	35	54	54				
19	Kodda 300 MW PP Unit-2 (Summit)	HFO (IPP)	18x17.076	300	300	195	195	300	300				
20	Kodda 149 MW PP Unit-1 (Summit)	HFO (IPP)	x18.415+1x8.9	149	149	109	133	149	149				
21	Nababganj 55 MW PP (Southern power )	HFO (IPP)	3x19.3	55	55	17	50	55	55				
22	Manikganj 55 MW PP (Northern)	HFO (IPP)	3x19.3	55	55	16	35	55	55				
23	Meghnaghat 104 MW PP (OPSL)	HFO (IPP)	6x18.5	104	104	0	0	104	104				
24	Manikganj 162MW PP(MPGL)	HFO (IPP)	9x18	162	162	35	86	162	162				
25	Manikganj 35MW Solar PP (Inspectra Solar Ltd.)	Solar (IPP)	1x35	35	35	33	0	32	0				
26	Kanchan Purbachal Power Generation Ltd.	HFO (IPP)	3x19.404	55	55	17	17	55	55				
	Keraniganj 100 MW PP (Powerpac)	HFO (NENP)	8x13.45										
27	Unique Meghnaghat 584MW CCGP	Gas (IPP)	1x400+1x184	584	584	460	420	584	584	164		Gas Shortage	
28	Meghnaghat 583 MW CCGP(Summit)	Gas (IPP)	1x390+1x193	583	583	0	0	583	583	583		Gas Shortage	
29	Meghnaghat (Jera) 718MW CCGP	Gas (IPP)	240'2+238	718	718	281	288	718	718	430		Gas Shortage	
30	Sripur 150 MW	HFO BR-Power gen	150	160	160	60	86	160	160				
<b>Dhaka Zone Total</b>				<b>6767</b>	<b>6608</b>	<b>2018</b>	<b>2225</b>	<b>5946</b>	<b>5914</b>	<b>3118</b>	<b>375</b>		
31	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro (PDB)	2x40, 3x50	230	230	80	82	40	40				
32	Chattogram TPP	Gas (PDB)	2 x 210	420	360	0	0	0	0	360		Gas Shortage	
33	Kaptai 7 MW Solar PP	Solar (PDB)	6	6	6	3.69	0	2	0				
34	Raozan 25 MW PP	HFO (RPCL)	3x8.9	25	25	0	17	26	26				
35	Teknaf 20MW PP (Solartech)	Solar (IPP)	1x20	20	20	12	0	12	0				
36	Patenga 50MW PP (Baraka)	HFO (IPP)	8x6.89	50	50	50	50	50	50				
37	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO (IPP)	6x18.415	105	105	37	45	105	105				
38	Shikalbaha Peaking GT	Gas (PDB)	1 x 150	150	150	0	0	0	0	150		Under maint.	
39	Sikalbaha 225 MW CCGP	Gas (PDB)	1 x 150+1 x 75	225	225	147	149	150	150				
40	Anwara 300 MW PP (United)	HFO (IPP)	17x17.076+ 3x8.9	300	300	0	0	300	300				
41	Juddah 100 MW PP Unit-3 (Acom)	HFO (IPP)	8x13.45	100	100	0	0	100	100				
42	Dohazari -Kalaish 100 MW Peaking	HFO (PDB)	6x17.0	102	98	0	50	51	51				
43	Hathazari 100 MW peaking PP	HFO (PDB)	11x8.9	98	98	0	0	48	64				
*	Malancha Ctg EPZ (United)	Gas	5x8.73+3x9.34			2	9	5	20				
44	Chattogram 108 MW PP (ECPV)	HFO (IPP)	16x7.00	108	108	0	38	108	108				
45	Sikalbaha 54 MW PP (Jodiak Power)	HFO (IPP)	3x18.55+1x3.6	54	54	0	0	54	54				
46	Karnaphuli Power Ltd.	HFO (IPP)	6x18.41+1x6.4	110	110	14	33	110	110				
47	Juddah unit-2 (Acom)	HFO (IPP)	8x13.6	100	100	0	0	100	100				
48	Chattogram 116 MW PP (Anima Energy Ltd.)	HFO (IPP)	6x21.06	116	116	5	30	116	116				
49	Mirsharai 150 MW	HFO BR-Power gen	9x18.5	163	160	6	0	163	163				
50	Chattogram 2'612MW Coal Based PP (SS Power)	Coal (IPP)	2x612	1224	1224	1160	1080	1224	1224				
51	Matarbari 2'600 MW (CPGCL)	Coal (CPGCL)	2x575	1150	1150	900	990	1150	1150				
52	Cox's Bazar Wind PP	(Wind) (IPP)	1x60	60	60	0	7	0	0				
<b>Chattogram Zone Total</b>				<b>4916</b>	<b>4849</b>	<b>2417</b>	<b>2580</b>	<b>3913</b>	<b>3931</b>	<b>360</b>	<b>150</b>		
53	Ashuganj 50 MW PP	Gas (APSCL)	14x3.968	53	47	0	0	42	42				
54	Ashuganj 225 MW CCGP	Gas (APSCL)	1x142+1'75	221	221	197	198	221.25	221.25				
55	Ashuganj 450 MW CCGP(South)	Gas (APSCL)	1x360	360	360	300	342	342.01	342.01				
56	Ashuganj 450 MW CCGP(North)	Gas (APSCL)	1x361	360	360	320	355	350	350				
57	Ashuganj 420 MW CCGP(East)	Gas (APSCL)	1x284+1x116	400	400	220	300	393	393				
58	Ashuganj 195MW PP (APSCL-United)	Gas (IPP)	20'9.73+1'16	195	195	0	0	195	195				
59	Ashuganj 51 MW PP (Midland)	Gas (IPP)	6x3.34	51	51	43	51	51	51				
60	Ashuganj 150MW PP (Midland)	HFO (IPP)	23x7.015	150	150	86	135	150	150				
61	Titas 50 MW Peaking PP	HFO (PDB)	6x8.92	52	52	0	31	32	32				
62	Chandpur 150 MW CCGP	Gas (PDB)	1X106+1x57	163	163	149	154	163	163				
63	Chandpur 200MW (Desh energy)	HFO (IPP)	12x18.415	200	200	38	66	200	200				
	Feni 11 MW PP (Doreen)	Gas (SIPP, REB)	4x2.90			0	0	0	0				
64	Jangalia 52 MW PP (Lakdanavi)	HFO (IPP)	6x8.92	52	52	0	0	52.2	52.2				
65	Cumilla 25 MW PP (Summit)	Gas (SIPP, REB)	3x3.67+2x6.97	25	25	19	19	24.5	24.5				
66	Feni 114 MW (Lakdanavi)	HFO (IPP)	11x18.415+1'9.7	114	114	0	0	114	114				
67	Chowmuhani 113 MW	HFO (IPP)	12'9.78+2'3.1	113	113	5	18	113	113				
68	Chandpur 115MW PP (Doreen)	HFO (IPP)	4x18.516+3x25.4	115	115	12	90	115	115				
69	Ashuani 55 MW PP (Precision)	Gas (NENP)	15'4	55	55	0	0	52.82	52.82				
70	Sonagazi 75 MW Solar Plant	(Solar) (EGCB)	1x75	75	75	62	0	60	0			Test run	
**	Impoport (Tripura)	India		160	160	132	152	84	80				
<b>Cumilla Zone Total</b>				<b>2914</b>	<b>2908</b>	<b>1583</b>	<b>1911</b>	<b>2754</b>	<b>2690</b>	<b>0</b>	<b>0</b>		
71	RPCL 210MW CCGP	Gas (IPP)	4x35+1x70	210	202	0	0	157.5	157.5	202		Gas Shortage	
72	Jamalpur 115 MW PP (United)	HFO (IPP)	12x9.87	115	115	87	88	90	90				
73	Mymensingh 200 MW PP (United)	HFO (IPP)	21x9.780	200	200	9	9	10	10				
74	Sarishabari 3 MW Solar Plant	Solar (IPP)	1x3	3	3	2.25	0	2.3	0				
75	Sutakhal 50 MW Solar PP	Solar (IPP)	1x50	50	50	45.69	0	45	0				
76	Bheirob 54 MW PP	HFO (IPP)	3x18.2	54	54	0	0	54.5	54.5				
77	Tangail 22 MW PP(PPGL)	HFO (IPP)	4x6.7	22	22	0	12	22	22				
<b>Mymensingh Zone Total</b>				<b>654</b>	<b>646</b>	<b>144</b>	<b>109</b>	<b>381</b>	<b>334</b>	<b>202</b>	<b>0</b>		

Sl. No.	Name of Power Station	Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	11-May-25 (Yesterday)		12-05-2026 (Today)		11.05.25 (Yesterday)		Status of Machines under shut-down/ Maintenance		
					Actual Peak Generation (MW)		Probable Peak Generation (MW)		Gen. shortfall for :		Description/ Remarks	Probable start-up date	
					Day	Evening	Day	Evening	Gas/Coal/Oil/Water Limitation MW	Machines shut down (MW)			
78	Fenchugonj CAPP Phase-1	Gas (PDB)	2x32+1x33	97	70	30	42	30	30				
79	Fenchugonj CAPP Phase-2	Gas (PDB)	2x35+1x35	104	90	30	30	30	30				
80	Kushara 163 MW CAPP (KP)	Gas (IPP)	1x109+1x54	163	163	150	148	163	163				
	Hobganga 11MW PP Confidence-E	Gas (SIPP, REB)	4x2.90										
81	Shahjibazar GTPP Unit- 8 & 9	Gas (PDB)	2x35	70	66	28	30	30	30				
82	Shahjibazar 330 MW CAPP	Gas (PDB)	2x110+1x110	330	330	0	0	100	100	35	Unit 9 Under maint.		
83	Sylhet 225 MW CAPP	Gas (PDB)	1x142+1x89	231	231	104	102	100	100	330	Gr-2 Under maint.		
84	Sylhet 20 MW GTPP	Gas (PDB)	1 x 20	20	20	0	0	20	20				
85	Shahjibazar 25 MW PP	Gas (CIPP, REB)	3x9.34	25	25	17	17	25	25				
86	Bibiana-II 341 MW CAPP (Summit)	Gas (IPP)	1x222+1x119	341	341	295	290	341	341				
87	Bibiyana-III 400 MW CAPP	Gas (PDB)	1x285+1x115	400	400	357	364	380	380				
88	Bibiyana South 383 MW CAPP	Gas (PDB)	1x252+1x131	383	383	0	0	0	0	383	HGPI Due		
89	Shahjibazar 100 MW GTPP	Gas (PDB)	1x100	100	100	0	0	0	0		Test run		
90	Shahjibazar 86MW PP (Shahjibazar)	Gas (NENP)	3x2.90	86	86	81	86	86	86				
91	Moulvibazar 10 MW Solar Power Plant	Solar IPP	1*10	10	10	12	0	0	0				
<b>Sylhet Zone Total</b>					<b>2360</b>	<b>2315</b>	<b>1104</b>	<b>1109</b>	<b>1305</b>	<b>1305</b>	<b>0</b>	<b>748</b>	
	Bheramara GTPP Unit- 3	HSD (PDB)	1 x 20			0	0	0	0				
92	Bheramara 410 MW CAPP	Gas (NWP/GCL)	x 278+1 x 13	410	410	195	220	410	410	190	Gas Shortage		
93	Fairpur 50 MW Peaking PP	HFO (PDB)	6x6.98	54	54	0	0	36	36				
94	Capalganj 100 MW Peaking PP	HFO (PDB)	16x6.98	109	109	0	0	50	50				
95	Khulna 225 MW CAPP	HSD/ Gas (NWP/GCL)	1 x 150+1x75	230	230	0	0	230	230				
96	Rupsha 102 MW PP (Orion rupsha)	HFO (IPP)	6x18.445	105	105	0	0	105	105				
97	Madhumati 100 MW PP	HFO (NWP/GCL)	6x18.415	105	105	0	0	105	105				
98	Mongla Orion 100 MW Solar PP	Solar (IPP)	100	100	99	0	95	0	0				
99	Maitree Super Thermal 1320 MW PP (U-1)	Coal (BIFPCL)	2x617	1234	1234	1052	1145	1234.2	1234.2				
99	Khulna 330 MW CAPP	Gas/HSD (BPDB)	1x220+1x116	336	336	0	0	0	0				
**	Rupsha 800 MW CAPP	Gas/HSD (NWP/GCL)										Test Run	
**	Bheramara (HVDC)	India		1000	1000	912	908	1000	1000				
**	Nepal	Nepal		40	40	0	0	0	0				
<b>Khulna Zone Total</b>					<b>3723</b>	<b>3723</b>	<b>2258</b>	<b>2273</b>	<b>3265</b>	<b>3170</b>	<b>190</b>	<b>0</b>	
100	Barisal 110 MW PP (Summit)	HFO (IPP)	7 x 17.076	110	110	0	32	110	110				
	Bhola 33 MW PP (Venture)	Gas (NENP)	1x34.50			0	0	0	0				
101	Bhola 225 MW CAPP	Gas (PDB)	2x63+1x68	194	194	127	127	130	130				
102	Payra 1320 MW TPP	Coal (BCPCL)	2x622	1244	1244	930	1060	1244	1244				
103	Potukhali 150MW PP (UPPL)	HFO (IPP)	x18.415+1x9.34	150	150	0	0	150	150				
104	Barisal Electric 307 MW	Coal (IPP)	1x307	307	307	251	230	307	307				
105	Barisal 1 MW Solar PP	Solar (BPDB)	1x1	1	1	0.7	0	1	0				
106	Bhola 220MW CAPP (Nutan Bidyt BD Ltd)	Gas/HSD (IPP)	2x75+1x70	220	220	220	220	220	220				
107	Patukhali 1320 MW (RNPL)	Coal RPCL	660*2	590	590	393	472	400	500			Coal Shortage	
<b>Barishal Zone Total</b>					<b>2816</b>	<b>2816</b>	<b>1922</b>	<b>2141</b>	<b>2562</b>	<b>2661</b>	<b>0</b>	<b>0</b>	
108	a) Baghabari 71 MW GTPP	Gas (PDB)	1 x 71	71	71	0	0	0	0	71	Gas Shortage		
	b) Baghabari 100 MW GTPP	Gas (PDB)	1 x 100	100	100	0	0	0	0	100	Under maint.		
109	Baghabari 50 MW Peaking PP	HFO (PDB)	6x8.9	52	52	0	0	40	40				
110	Bera 70 MW Peaking PP	HFO (PDB)	9x8.29	71	71	0	0	30	30				
111	Chapainawabganj 100 MW Peaking PP	HFO (PDB)	12x8.924	104	104	0	0	92	92				
112	Katakhalhi 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	32	32				
113	Santahar 50 MW Peaking PP	HFO (PDB)	6x8.7	50	50	0	0	25	25				
114	Sirajgonj 225MW CAPP Unit-1	Gas (NWP/GCL)	1x150+1x75	210	210	160	150	214	214	60	Gas Shortage		
115	Sirajgonj 225MW CAPP Unit-2	Gas (NWP/GCL)	1x150+1x75	220	220	0	0	220	220	220	Gas Shortage		
116	Sirajgonj 225MW CAPP Unit-3	Gas (NWP/GCL)	1x141+1x79	220	220	130	150	220	220	70	Gas Shortage		
117	Sirajgonj 400 MW CAPP Unit-4	Gas (IPP)	1x282+1x132	414	414	414	362	413.79	413.79				
	Ullapara 11 MW PP (Summit)	Gas (SIPP, REB)	4x2.90										
118	Natore 52 MW PP (Rajlanka)	HFO (IPP)	6x8.92	52	52	0	0	52.2	52.2				
119	Bagura 113 MW PP (Confidence) U-1	HFO (IPP)	6*18.55	113	113	0	35	113	113				
120	Bagura 113 MW PP (Confidence) U-2	HFO (IPP)	6x18.55	113	113	0	35	113	113				
	Amnura 50 MW PP(Sinha)	HFO (NENP)	7x7.79										
121	Sirajgonj 6.55 MW Solar	Solar (NWP/GCL)	1x6	6	6	4.97	0	6	0				
122	Sirajgonj 68 MW Solar Park	Solar (IPP)	68	68	68	41	0	61	0				
123	Pabna Solar 100 MW	Solar (IPP)	100	100	100	81	0	80	0				
124	Sirajgonj 2 MW Wind Power Plant	Wind (BPDB)	2	2	0	0	0	0	0				
125	Pabna 64 MW Solar Plant		65	65	58.5	0	61.55	0	0				
126	Adani Power Jharkhanda Ltd	(Import)	2x748	1496	1436	1225	1286	1436	1436				
<b>Rajshahi Zone Total</b>					<b>3577</b>	<b>3517</b>	<b>2115</b>	<b>2018</b>	<b>3209</b>	<b>3001</b>	<b>421</b>	<b>100</b>	
127	Barapukuria TPP Unit-1 & 2	Coal (PDB)	2x 125	250	170	50	49	50	50	121	Under maint U-2		
128	Barapukuria 275 MW TPP Unit-3	Coal (PDB)	1 x 274	274	274	0	0	0	0	274	Under maint		
129	Rangpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	20	20				
130	Rangpur 113 MW PP (Confidence)	HFO (IPP)	7*18x 2*3	113	113	0	88	113	113				
131	Saidpur 20 MW GTPP	HSD (PDB)	1 x 20	20	20	0	0	0	0				
132	Majpara. Tutulia 8 MW Solar PP (Sympa Power)	Solar (IPP)	1 x 8	8	8	6.7	0	6	0				
133	Thakurgaon 115MW PP (Energypac)	HFO (IPP)	6*20	115	115	0	108	115	115				
134	Lalmonirhat 30 MW Solar (Intraco)	Solar (IPP)	1*30	30	30	33	0	30	0				
135	Teesta Solar Limited	Solar (IPP)	1 x 200	200	200	199	0	200	0				
136	Saidpur 150 MW Simple Cycle Power Plant	HSD PDB	1*150	162	162	0	0	0	0				
<b>Rangpur Zone Total</b>					<b>1192</b>	<b>1112</b>	<b>289</b>	<b>245</b>	<b>534</b>	<b>298</b>	<b>0</b>	<b>395</b>	
<b>Sub-total: Plants in operation</b>					<b>28919</b>	<b>28494</b>	<b>13848.6</b>	<b>14611</b>	<b>23871</b>	<b>23305</b>	<b>4291</b>	<b>1768</b>	
<b>(b) Plants under long term maintenance/ contract expired</b>													
Sub-total: Plants under long term maintenance/ contract expired					0	0	0	0	0	0	0	0	
<b>136 Gross Total</b>					<b>28919</b>	<b>28494</b>	<b>13849</b>	<b>14611</b>	<b>23871</b>	<b>23305</b>	<b>4291</b>	<b>1768</b>	
<b>(C) Actual data of 11.05.25 Yesterday Sunday :</b>													
01.	Max. Demand at eve. peak (Generation end)	: 14750 MW, at = 19:30 Hr.											
02.	Evening-peak Generation (Generation end)	: 14611 MW, at = 19:30 Hr.											
03.	Highest Generation (Generation end)	: 14611 MW, at = 19:30 Hr.											
04.	Day Peak Demand	: 13880 MW, at = 12:00 Hr.											
05.	Day-peak Generation (Generation end)	: 13849 MW, at = 12:00 Hr.											
06.	Minimum Generation (Generation end)	: 11332 MW, at = 05:00 Hr.											
	Evening Peak Load-shed (Sub-station end)	: 133 MW, at = 05:00 Hr.											
07.	Generation shortfall at evening peak due to :	:											
a)	Gas/LF limitation	: 4291 MW											
d)	Coal supply Limitation	: 0 MW											
b)	Low water level in Kaptai lake	: 0 MW											
c)	Plants under shut down/ maintenance	: 1768 MW											
08.	Total Energy (Generation + Import)	: 313.18 MKWh											
	By Gas =	124.528 MKWh	By Oil =	18.264 MKWh									
	By Coal =	109.969 MKWh	Hydro/Wind=	1.688 MKWh									
	By Solar=	4.896 MKWh	Imported=	53.831 MKWh									
09.	Total Gas Supplied	: 915 MCFD											
<b>(D) Forecast of 12-05-2026 (Today) :</b>													
01.	Probable Maximum Demand at Day Peak:	14000.00 MW											
02.	Probable Maximum Demand at Evening Peak:	15100.00 MW											
03.	Probable Maximum Generation at Evening Peak:	15100.00 MW											
04.	Probable Load Shed:	0	At evening peak (Sub-station end)										
05.	Probable Total Energy Generation:	321.00 MKWhr.											
06.	Probable Maximum Temperature:	32.00°C											
* Active Power ** Imported Power													
#Remarks: Highest Generation 16794 MW on 23-07-2025 at 21:00													
(Md. Helatur Rahman) Deputy Secretary, Generation													