Bangladesh Power Development Board

DAILY ELECTRICITY GENERATION REPORT (HFO Based)

Office of the Member, Generation
Tel : 9564667, 9551095

Month September, 2026 | Day: **Saturday** | Date : **26-09-2026**

Probable Maximum Demand : 16560.00 MW | **Probable Maximum Generation : 15150.00 MW**

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25-Sep-26 (Yesterday) Actual Peak Generation (MW)		26-09-2026 (Today) Probable Peak Generation (MW)		25.09.26 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
(A)	**Plants in operation:**													
1	Ghorasal Repowered CCPP Unit-3 (GT)	Gas	(PDB)	1 x 260	260	260	0	0	0	0		260	Under project work	
2	a) Ghorasal Repowered CCPP Unit-4	Gas	(PDB)	1 x 210	210	180	0	0	230	230	180		Gas Shortage	
	b) Ghorasal TPP Unit-5	Gas	(PDB)	1 x 210	210	190	0	0	190	190	190		Gas Shortage	
3	Ghorasal 365 MW CCPP Unit-7	Gas	(PDB)	1x 254+1x 126	365	365	0	0	260	260	365		Gas Shortage	
4	Ghorashal 108MW PP (Regent)	Gas	(IPP)	34x3.35	108	99	0	0	100	100	99		Gas Shortage	
5	Tongi 80 MW GTPP	Gas	(PDB)	1 x 105	105	105	0	0	0	0	105		Gas Shortage	
	Haripur GTPP	Gas	(PDB)	1 x 32			0	0	0	0				
6	Meghnaghat 450 MW CCPP(MPL)	Gas	(IPP)	2x140+1x170	450	450	0	0	0	0			Contract Expired	
7	210 MW Siddhirgonj TPP	Gas	(PDB)	1 x 210	210	115	0	0	0	0		115	Under Overhauling	
8	Haripur 412 MW CCPP	Gas	(EGCB)	1x273+1x139	412	412	344	337	412	412				
9	Siddhirgonj 2*120 MW GTPP	Gas	(EGCB)	2 x 105	210	210	0	0	210	210	210		Gas Shortage	
10	Siddhirganj 335 MW CCPP	Gas	(EGCB)	1 x 217+1x118	335	335	230	260	335	335				
11	Meghnaghat 335MW CCPP(Summit)	Gas	(IPP)	2x110+1x110	335	335	250	303	335	335				
12	Madanganj-55 MW PP(Summit)	HFO	(IPP)	6x17.08+1x11.	55	55	10	0	55	55				
13	Gagnagar 102 MW PP (Digital Power)	HFO	(IPP)	12x8.924	102	102	0	0	102	102				
	Narshingdi 22 MW PP (Doreen)	Gas	(SIPP, REB)	8x2.90			0	0	0	0				
14	Summit Power Ashulia	Gas	(SIPP, REB)	6x3.67+7x8.73	45	45	4.8	11.8	33	33				
	Summit Power Madhabdi	Gas	(SIPP, REB)	6x3.67+7x8.73	35	35	22	22	22	22				
	Maona 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73										
	Rupganj 33 MW PP(Summit)	Gas	(SIPP, REB)	4x8.73										
15	Gazipur 52 MW PP	HFO	(RPCL)	6x8.90	52	52	8	8	52	52				
16	Gazipur 100 MW PP	HFO	(RPCL)	6x18.415	105	105	17	17	105	105				
17	Kodda 150MW PP	HFO	BR-Power gen	9x17.06	149	149	60	13	149	149				
18	Kamalaghat 54 MW PP (Banco Energy)	HFO	(IPP)	3x18.69	54	54	17	50	54	54				
19	Kodda 300 MW PP Unit-2 (Summit)	HFO	(IPP)	18x17.076	300	300	70	45	300	300				
20	Kodda 149 MW PP Unit-1 (Summit)	HFO	(IPP)	x18.415+1x8.9	149	149	72	70	149	149				
21	Nababganj 55 MW PP (Southern power)	HFO	(IPP)	3x19.3	55	55	17	35	55	55				
22	Manikganj 55 MW PP (Northern)	HFO	(IPP)	3x19.3	55	55	17	17	55	55				
23	Meghnaghat 104 MW PP (OPSL)	HFO	(IPP)	6x18.5	104	104	0	0	104	104				
24	Manikgonj 162MW PP(MPGL)	HFO	(IPP)	9x18	162	162	35	160	162	162				
25	Manikgonj 35MW Solar PP (Inspectra Solar Ltd.)	Solar	(IPP)	1x35	35	35	40	0	32	0				
26	Kanchan Purbachal Power Generation Ltd.	HFO	(IPP)	3x19.404	55	55	8	17	55	55				
	Keraniganj 100 MW PP (Powerpac)	HFO	(NENP)	8x13.45										
27	Unique Meghnaghat 584MW CCPP	Gas	(IPP)	1x400+1x184	584	584	340	445	584	584	139		Gas Shortage	
28	Meghnaghat 583 MW CCPP(Summit)	Gas	(IPP)	1x390+1x193	583	583	0	0	583	583	583		Gas Shortage	
29	Meghnaghat (Jera) 718MW CCPP	Gas	(IPP)	240*2+238	718	718	0	0	718	718	718		Gas Shortage	
30	Sripur 150 MW	HFO	BR-Power gen	150	160	160	34	143.42	143.42	143.42				
	Dhaka Zone Total				**6767**	**6613**	**1596**	**1954**	**5585**	**5553**	**2589**	**375**		
31	Karnaphuli Hydro PP Unit-1,2,3,4, 5	Hydro	(PDB)	2x40, 3x50	230	230	218	222	222	222				
32	Chattogram TPP	Gas	(PDB)	2 x 210	420	360	0	0	0	0	360		Gas Shortage	
33	Kaptai 7 MW Solar PP	Solar	(PDB)		6	6	4.85	0	5	0				
34	Raozan 25 MW PP	HFO	(RPCL)	3x8.9	25	25	0	0	26	26				
35	Teknaf 20MW PP (Solartech)	Solar	(IPP)	1x20	20	20	19	0	18	0				
36	Patenga 50MW PP (Baraka)	HFO	(IPP)	8x6.89	50	50	0	6	50	50				
37	Sikalbaha 105 MW PP (Baraka Sikalbaha)	HFO	(IPP)	6x18.415	105	105	31	68	105	105				
38	Shikalbaha Peaking GT	Gas	(PDB)	1 x 150	150	150	0	0	0	0		150	Under maint.	
39	Sikalbaha 225 MW CCPP	Gas	(PDB)	1 x 150+1 x 75	225	225	211	221	215	215				
40	Anwara 300 MW PP (United)	HFO	(IPP)	17x17.076+ 3x8.04	300	300	80	45	300	300				
41	Juldah 100 MW PP Unit-3 (Acorn)	HFO	(IPP)	8x13.45	100	100	0	0	100	100				
42	Dohazari -Kalaish 100 MW Peaking	HFO	(PDB)	6x17.0	102	98	0	34	34	34				
43	Hathazari 100 MW peaking PP	HFO	(PDB)	11x8.9	98	98	0	52	24	50				
*	Malancha, Ctg.EPZ (United)	Gas		5x8.73+3x9.34			14	38	42	42				
44	Chattogram 108 MW PP (ECPV)	HFO	(IPP)	16x7.00	108	108	0	0	95.1	95.1				
45	Sikalbaha 54 MW PP(Jodiac Power)	HFO	(IPP)	3x18.55+1x3.6	54	54	35	54.36	54	54				
46	Karnaphuli Power Ltd.	HFO	(IPP)	6x18.41+1x6.4	110	110	0	0	110	110				
47	Juldah unit-2 (Acorn)	HFO	(IPP)	8x13.6	100	100	50	36	100	100				
48	Chattogram 116 MW PP (Anlima Energy Ltd.)	HFO	(IPP)	6x21.06	116	116	16	0	116	116				
49	Mirsharai 150 MW	HFO	BR-Power gen	9x18.5	163	163	30	16	163	163				
50	Chattogram 2*612MW Coal Based PP (SS Power)	Coal	(IPP)	2x612	1224	1224	1156	1224	1224	1224				
51	Matarbari 2*600 MW (CPGCL)	Coal	(CPGCL)	2x575	1150	1056	620	1050	1150	1150				
52	Cox's Bazar Wind PP	(Wind)	(IPP)	1x60	60	60	37	21	4	0				
	Chattogram Zone Total				**4916**	**4758**	**2522**	**3087**	**4156**	**4156**	**360**	**150**		
53	Ashuganj 50 MW PP	Gas	(APSCL)	14x3.968	53	47	0	0	42	42				
54	Ashuganj 225 MW CCPP	Gas	(APSCL)	1×142+1*75	221	221	190	214	221.25	221.25				
55	Ashuganj 450 MW CCPP(South)	Gas	(APSCL)	1x360	360	319	250	335	342.01	342.01				
56	Ashuganj 450 MW CCPP(North)	Gas	(APSCL)	1x361	360	353	288	355	350	350				
57	Ashuganj 420 MW CCPP(East)	Gas	(APSCL)	1x284+1x116	400	393	220	220	393	393				
58	Ashuganj 195MW PP (APSCL-United)	Gas	(IPP)	20*9.73+1*16	195	195	0	0	195	195	195		Gas Shortage	
59	Ashuganj 51 MW PP (Midland)	Gas	(IPP)	6x9.34	51	51	44	44	51	51				
60	Ashuganj 150MW PP (Midland)	HFO	(IPP)	23x7.015	150	150	11	108	150	150				
61	Titas 50 MW Peaking PP	HFO	(PDB)	6x8.92	52	52	3	23	21	21				
62	Chandpur 150 MW CCPP	Gas	(PDB)	1X106+1x57	163	163	110	109	163	163				
63	Chandpur 200MW (Desh energy)	HFO	(IPP)	12x18.415	200	200	15	16	200	200				
	Feni 11 MW PP (Doreen)	Gas	(SIPP, REB)	4x2.90			0	0	0	0				
64	Jangalia 52 MW PP (Lakdanavi)	HFO	(IPP)	6x8.92	52	52	0	0	52.2	52.2				
65	Cumilla 25 MW PP (Summit)	Gas	(SIPP, REB)	3x3.67+2x6.93	25	25	19	19	24.5	24.5				
66	Feni 114 MW (Lakdanavi)	HFO	(IPP)	7*18.415+1*9.7	114	114	0	0	114	114				
67	Chowmuhani 113 MW	HFO	(IPP)	12*9.78+2*3.1	113	113	44	73	113	113				
68	Chandpur 115MW PP (Doreen)	HFO	(IPP)	4x18.516+2x25.4	115	115	21	15	115	115				
69	Ashuganj 55 MW PP (Precision)	Gas	(NENP)	15*4 (29, 53)	55	53	0	0	52.82	52.82				
70	Sonagazi 75 MW Solar Plant	(Solar)	(EGCB)	1x75	75	75	51	0	70	0				
**	Impoprt (Tripura)		India		160	160	60	78	84	78				
	Cumilla Zone Total				**2914**	**2851**	**1326**	**1609**	**2753**	**2677**	**195**	**0**		
71	RPCL 210MW CCPP	Gas	(IPP)	4x35+1x70	210	210	0	0	210	210	210		Gas Shortage	
72	Jamalpur 115 MW PP (United)	HFO	(IPP)	12x9.87	115	115	68	65	60	90				
73	Mymensingh 200 MW PP (United)	HFO	(IPP)	21x9.780	200	200	106	140	120	170				
74	Muktagacha Solartech Energy Ltd	Solar	(IPP)	1x20	20	20	13.66	0	12	0				
75	Sarishabari 3 MW Solar Plant	Solar	(IPP)	1x3	3	3	1.1	0	2	0				
76	Sutiakhali 50 MW Solar PP	Solar	(IPP)	1x50	50	50	38.18	0	50	0				
77	Bhairob 54 MW PP	HFO	(IPP)	3x18.2	54	54	0	17	54.5	54.5				
78	Tangail 22 MW PP(PPGL)	HFO	(IPP)	4x6.7	22	22	0	18	22	22				
	Mymensing Zone Total				**674**	**674**	**227**	**240**	**531**	**547**	**210**	**0**		

Sl. No.	Name of Power Station			Nos. of Unit X Capacity (MW)	Installed Capacity (MW)	Derated/ Present Capacity (MW)	25-Sep-26 (Yesterday) Actual Peak Generation (MW)		26-09-2026 (Today) Probable Peak Generation (MW)		25.09.26 (Yesterday) Gen. shortfall for :		Status of Machines under shut-down/ Maintenance	
							Day	Evening	Day	Evening	Gas/Coal/oil/Water Limitation MW	Machines shut down (MW)	Description/ Remarks	Probable start-up date
79	Fenchugonj CCPP Phase-1	Gas	(PDB)	2x32+1x33	97	70	28	29	30	30				
80	Fenchugonj CCPP Phase-2	Gas	(PDB)	2x35+1x35	104	90	29	30	30	30	60		Gas Shortage	
81	Kushiara 163 MW CCPP (KP)	Gas	(IPP)	1x109+1x54	163	163	0	0	0	0		163	Under maint.	
	Hobiganj 11MW PP Cofidence-E	Gas	(SIPP, REB)	4x2.90										
82	Shahjibazar GTPP Unit- 8 & 9	Gas	(PDB)	2x35	70	66	0	30	30	30		35	Unit-9 Under maint.	
83	Shajibazar 330 MW CCPP	Gas	(PDB)	2x110+1x110	330	330	113	138	0	0		192	Gt-2 Under maint.	
84	Sylhet 225 MW CCPP	Gas	(PDB)	1x142+1x89	231	231	0	0	100	100				
85	Sylhet 20 MW GTPP	Gas	(PDB)	1 x 20	20	20	0	0	0	0				
86	Shahjahanulla 25 MW PP	Gas	(CIPP, REB)	3x9.34	25	25	15	8	16	16				
87	Bibiana-II 341 MW CCPP (Summit)	Gas	(IPP)	1x222+1x119	341	341	310	280	341	341				
88	Bibiyana-III 400 MW CCPP	Gas	(PDB)	1x285+1x115	400	400	274	274	280	280				
89	Bibiyana South 383 MW CCPP	Gas	(PDB)	1x252+1x131	383	383	384	398	383	383				
90	Shahjibazar 100 MW GTPP	Gas	(PDB)	1x100	100	100	0	0	0	0		100	Under maint.	
91	Shahjibazar 86MW PP (Shahjibazar)	Gas	(NENP)	32x2.90	86	86	76	81	84	84				
92	Moulvibazar 10 MW Solar Power Plant	Solar	IPP	1*10	10	10	9	0	0	0				
	Sylhet Zone Total				**2360**	**2315**	**1238**	**1268**	**1294**	**1294**	**60**	**490**		
	Bheramara GTPP Unit- 3	HSD	(PDB)	1 x 20			0	0	0	0				
93	Bheramara 410 MW CCPP	Gas	(NWPGCL)	x 278+1 x 13	410	410	0	0	410	410	410		Gas Shortage	
94	Faridpur 50 MW Peaking PP	HFO	(PDB)	8x6.98	54	54	0	32	32	32				
95	Gopalganj 100 MW Peaking PP	HFO	(PDB)	16x6.98	109	109	0	32	50	50				
96	Khulna 225 MW CCPP	HSD/ Gas	(NWPGCL)	1 x 150+1x75	230	230	0	0	230	230				
97	Rupsha 105 MW PP (Orion rupsha)	HFO	(IPP)	6x18.445	105	105	0	0	105	105				
98	Madhumati 100 MW PP	HFO	(NWPGCL)	6x18.415	105	105	0	0	105	105				
99	Mongla Orion 100 MW Solar PP	Solar	(IPP)		100	100	100	0	70	0				
100	Maitree Super Thermal 1320 MW PP (U-1)	Coal	(BIFPCL)	2x617	1234	1148	1194	1234.2	1234.2	1234.2				
100	Khulna 330 MW CCPP	Gas/HSD	(BPDB)	1x220+1x116	336	336	0	0	330	330				
**	Rupsha 800 MW CCPP	Gas/HSD	(NWPGCL)										Commissioning running	
**	Bheramara (HVDC)		India		1000	1000	911	922	1000	1000				
**	Nepal		Nepal		40	40	0	0	40	40				
	Khulna Zone Total				**3723**	**3637**	**2205**	**2220**	**3606**	**3536**	**410**	**0**		
101	Barisal 110 MW PP (Summit)	HFO	(IPP)	7 x 17.076	110	110	16	15	110	110				
	Bhola 33 MW PP (Venture)	Gas	(NENP)	1x34.50			0	0	0	0				
102	Bhola 225 MW CCPP	Gas	(PDB)	2x63+1x68	194	194	115	115	120	120				
103	Payra 1320 MW TPP	Coal	(BCPCL)	2x622	1244	1086	300	300	300	300		786	Under maint	
104	Potuakhali 150MW PP (UPPL)	HFO	(IPP)	x18.415+1x9.7	150	150	35	90	150	150				
105	Barisal Electric 307 MW	Coal	(IPP)	1x307	307	307	280	280	307	307				
106	Barisal 1 MW Solar PP	Solar	(BPDB)	1x1	1	1	0.81	0	1	0				
107	Bhola 220MW CCPP (Nutan Bidyut BD Ltd)	Gas/HSD	(IPP)	2x75+1x70	220	220	180	220	220	220				
108	Patuakhali 1320 MW (RNPL)	Coal	RPCL	660*2	1244	1244	982	1100	1000	1100	144		Coal Shortage	
	Barishal Zone Total				**3470**	**3312**	**1909**	**2120**	**2208**	**2307**	**144**	**786**		
109	a) Baghabari 71 MW GTPP	Gas	(PDB)	1 x 71	71	71	0	0	0	0	71		Gas Shortage	
	b) Baghabari 100 MW GTPP	Gas	(PDB)	1 x 100	100	100	0	0	0	0		100	Under maint.	
110	Baghabari 50 MW Peaking PP	HFO	(PDB)	6x8.9	52	52	0	39	40	40				
111	Bera 70 MW Peaking PP	HFO	(PDB)	9x8.29	71	71	0	0	32	32				
112	Chapainawabganj 100 MW Peaking PP	HFO	(PDB)	12x8.924	104	104	0	50	100	100				
113	Katakhali 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	36	40	40				
114	Santahar 50 MW Peaking PP	HFO	(PDB)	6x8.7	50	50	0	34	32	32				
115	Sirajgonj 225MW CCPP Unit-1	Gas	(NWPGCL)	1x150+1x75	210	214	127	129	214	214	85		Gas Shortage	
116	Sirajgonj 225MW CCPP Unit-2	Gas	(NWPGCL)	1x150 + 1x75	220	220	0	0	220	220	220		Gas Shortage	
117	Sirajgonj 225MW CCPP Unit-3	Gas	(NWPGCL)	1x141+1x79	220	220	0	0	220	220	220		Gas Shortage	
118	Sirajgonj 400 MW CCPP Unit-4	Gas	(IPP)	1x282+1x132	414	414	244	304	413.79	413.79				
	Ullapara 11 MW PP (Summit)	Gas	(SIPP, REB)	4x2.90										
119	Natore 52 MW PP (Rajlanka)	HFO	(IPP)	6x8.92	52	52	0	0	52.2	52.2				
120	Bagura 113 MW (Confidence) U-1	HFO	(IPP)	6*18.55	113	113	50	113	113	113				
121	Bagura 113 MW PP (Confidence) U-2	HFO	(IPP)	6x18.55	113	113	5	35	113	113				
	Amnura 50 MW PP(Sinha)	HFO	(NENP)	7x7.79										
122	Sirajgonj 6.55 MW Solar	Solar	(NWPGCL)	1x6	6	6	3.3	0	6	0				
123	Sirajganj 68 MW Solar Park	Solar	(IPP)	68	68	68	39	0	64	0				
124	Pabna Solar 100 MW	Solar	(IPP)	100	100	100	80	0	100	0				
125	Sirajgonj 2 MW Wind Power Plant	Wind	(BPDB)		2	2	0	0	0	0				
126	Pabna 64 MW Solar Plant				65	65	45.02	0	51.42	0				
127	Adani Power Jharkhanda Ltd		(Import)	2x748	1496	1436	933	1293	1200	1300				
	Rajshahi Zone Total				**3577**	**3521**	**1526**	**2033**	**3011**	**2890**	**596**	**100**		
128	Barapukuria TPP Unit-1 &2	Coal	(PDB)	2x 125	250	170	50	49	49	49		121	Under maint U-2	
129	Barapukuria 275 MW TPP Unit-3	Coal	(PDB)	1 x 274	274	274	156	159	160	160		115	ID Fan Problem	
130	Rangpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	20	20				
131	Rangpur 113 MW PP (Confidence)	HFO	(IPP)	7*16x 2*3	113	113	45	113	113	113				
132	Saidpur 20 MW GTPP	HSD	(PDB)	1 x 20	20	20	0	0	0	0				
133	Majipara, Tatulia 8 MW Solar PP (Sympa Power)	Solar	(IPP)	1 x 8	8	8	0	0	3	0				
134	Thakurgaon 115MW PP (Energypac)	HFO	(IPP)	6*20	115	115	18	0	115	115				
135	Lalmonirhat 30 MW Solar (Intraco)	Solar	(IPP)	1*30	30	30	14	0	28	0				
136	Teesta Solar Limited	Solar	(IPP)	1 x 200	200	200	37	0	161.66	0				
137	Saidpur 150 MW Simple Cycle Power Plant	HSD	PDB	1*150	162	162	0	0	0	0				
	Rangpur Zone Total				**1192**	**1112**	**320**	**321**	**650**	**457**	**0**	**236**		
	Sub-total: Plants in operation				**29593**	**28793**	**12868.3**	**14853**	**23794**	**23417**	**4564**	**2137**		
(B) Plants under long term maintenance/ contract expired														
	Sub-Total: Plants under long term maintenance/ contract expired					0	0	0	0	0	0	0		
137	**Gross Total**				**29593**	**28793**	**12868**	**14853**	**23794**	**23417**	**4564**	**2137**		

(C) Actual data of 25.09.26 Yesterday Friday :

01.	Max. Demand at eve. peak (Generation end)	:	**15088** MW, at =	**21:00 Hr.**
02.	Evening-peak Generation (Generation end)	:	**14853** MW, at =	**21:00 Hr.**
03.	Highest Generation (Generation end)	:	**14853** MW, at =	**21:00 Hr.**
04.	Day Peak Demand	:	**13307** MW, at =	**12:00 Hr.**
05.	Day-peak Generation (Generation end)	:	**12868** MW, at =	**12:00 Hr.**
06.	Minimum Generation (Generation end)	:	**12000** MW, at =	**10:00 Hr.**
	Evening Peak Load-shed (Sub-station end)	:	**225** MW, at =	**10:00 Hr.**
07.	Generation shortfall at evening peak due to :	:		
	a) Gas/LF limitation	:	**4564** MW	
	d) Coal supply Limitation	:	**0** MW	
	b) Low water level in Kaptai lake	:	**0** MW	
	c) Plants under shut down/ maintenance	:	**2137** MW	
08.	Total Energy (Generation + Import)	:	**324.77** MKWh	
	By Gas = 113.100 MKWH		By Oil = 33.058 MKWh	
	By Coal = 120.647 MKWH		r Hydro&Wind= 6.031 MKWh	
	By Solar= 3.281 MKWH		Imported= 48.649 MKWh	
09.	Total Gas Supplied	:	**830** MMCFD	

10. Zone wise Demand and Load-shed at Evening Peak (Sub-station end) :

Zone	Demand MW	Supply MW	Load Shed MW	Zone	Demand MW	Supply MW	Load Shed MW
Dhaka	**5294**	**5294**	**0**	Mymensingh	**1229**	**1211**	**18**
Chattogram	**1491**	**1491**	**0**	Sylhet	**720**	**513**	**207**
Khulna	**1692**	**1692**	**0**	Barishal	**457**	**457**	**0**
Rajshahi	**1344**	**1344**	**0**	Rangpur	**826**	**826**	**0**
Cumilla	**1478**	**1478**	**0**				
				Total	**14531**	**14306**	**225**

11.	Fuel cost :	(a) Gas =	**393946200** Taka	(c) Coal =	**876662778**	Taka
		(b) Oil =	**645410423** Taka	(d) Renewable	**62247702**	Taka
		(e)Import=	**302645601** Taka	Total =	**2280912704**	Taka

12.	Maximum Temperature:	**32.8**
13.	Energy Flow from East to West:	**0**
14.	Energy Flow from West to East:	**49959654.54**
15.	Power Flow during Peak Demand (W-E):	**2078**
16.	Maximum Power Flow (W-E):	**2561**

(D) Forecast of 26-09-2026 (Today) :

01.	Probable Maximum Demand at Day Peak:	**14290.00 MW**	04.	Probable Load Shed: **0** At evening peak (Sub-station end)
02.	Probable Maximum Demand at Evening Peak:	**16560.00 MW**	05.	Probable Total Energy Generation: **321.43 MKWHr.**
03.	Probable Maximum Generation at Evening Peak:	**15150.00 MW**	06.	Probable Maximum Temperature: **33.00°C**

* Captive Power ** Imported Power

#Remarks: Highest Generation 17200 MW on 20-05-2026 at 21:00

(Md. Helalur Rahman)
Deputy Secretary, Generation